

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

822093

Permit Number 3895

COUNTY MAHONING

TOWNSHIP CANFIELD

SECTION/LOT No.
(Circle One)

OWNER/BUILDER ROBERT DUPONTY
(Circle One or Both) First Last

PROPERTY ADDRESS 7240 PALMYRA RD. CANFIELD
(Address of well location) Number Street City

LOCATION OF PROPERTY 1 MILE SOUTH OF RT. 224

Zip Code + 4 44406

CONSTRUCTION DETAILS

CASING (Length below grade)		Borehole Diameter	6 in.	GROUT					
1) Diameter	6 in.	Length*	54 ft.	Wall Thickness	.188 in.	Material		Volume used	
2) Diameter		Length*		Wall Thickness		Method of installation			
Type:	☒ Steel	☐ Galv.	☐ PVC	☐ Other		Depth: placed from		ft. to	
Joints:	☐ Threaded	☒ Welded	☐ Solvent	☐ Other		GRAVEL PACK (Filter Pack)			
Liner:	Length	Type	Wall Thickness			Material		Volume used	
SCREEN									
Type (wire wrapped, louvered, etc.)				Material					
Length				ft.	Diameter				
Set between				ft.	and	ft.	Slot		
				Pitless Device ☒ Adapter ☐ Preassembled unit					
				Use of Well <u>RESIDENTIAL</u>					
				in. ☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other					
				Date of Completion <u>9-10-97</u>					

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
YELLOW CLAY	0	5
YELLOW SANDY CLAY	5	20
GRAY SANDY CLAY	20	25
DARK GRAY SANDY CLAY	25	40
LIGHT GRAY SANDY SHALE	40	68
DARK GRAY SANDY SHALE	68	85
LIGHT GRAY SANDY SHALE	85	102
DARK GRAY SHALE	102	145
LIGHT GRAY SHALE	145	151
DARK GRAY SANDSTONE	151	170

WELL TEST

☒ Bailing	☒ Pumping*	☐ Other	
Test rate	35 gpm	Duration of test	4 hrs.
Drawdown	40		ft.
Measured from:	☐ top of casing	☒ ground level	☐ Other
Static Level (depth to water)	52	ft.	Date: 9-10-97
Quality (clear, cloudy, taste, odor)	CLEAR		
*(Attach a copy of the pumping test record, per section 1521.05, ORC)			


PUMP

Type of pump	SUBMERSIBLE	Capacity	8	gpm
Pump set at	160			ft.
Pump installed by	LININGER DRILLING			

WELL LOCATION

Location of well in State Plane coordinates, if available:
Zone x y
Elevation of well ft./m. Datum plain: ☐ NAD27 ☐ INAD83
Source of coordinates: ☐ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.



*(If additional space is needed to complete well log, use next consecutively numbered form.) I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm LININGER DRILLING & PUMPS, INC.
Address 146 COLLEGE AVE.
City, State, Zip GREENVILLE, PA 16125

Signed Richard Lininger
Date 10-17-97

ODH Registration Number 476