DNR 7802.94
TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Divison of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

823032

Permit Number 98-178

COUNTY FAIRFIELD TOWNSHIP WALNUT SECTION/LOT No. (Circle One)

OWNER/BUILDER (Circle One or Both) JUDY (First) LONE (Last) PROPERTY ADDRESS (Address of well location) 8686 NEW SALEM (Number) RD (Street) PLEASANTVILLE (City) OHIO (Zip Code + 4)

LOCATION OF PROPERTY

CONSTRUCTION DETAILS

CASING *(Length below grade) Borehole Diameter 5 1/2 in.

1 Diameter 5 1/2 in. Length* 43 ft. Wall Thickness 1/4 in.

2 Diameter in. Length* ft. Wall Thickness in.

Type: 1 Steel 2 | 1 Galv. 2 | 1 PVC 2 | 1 2 Other

Joints: 1 Threaded 2 | 1 Welded 2 | 1 Solvent 2 | 1 2 Other

Liner: Length Type Wall Thickness in.

SCREEN

Type (wire wrapped, louvered, etc.) DRILLED Material STEEL

Length ft. Diameter 5 1/2 in.

Set between 43 ft. and BOTTOM ft. Slot OPP

GROUT

Material Volume used

Method of installation

Depth: placed from ft. to ft.

GRAVEL PACK (Filter Pack)

Material Volume used

Method of installation

Depth: placed from ft. to ft.

Pitless Device | Adapter | Preassembled unit

Use of Well FAMILY DWELLING

| Rotary | Cable | Augered | Driven | Dug | Other

Date of Completion 6-7-98

WELL LOG* BOTTOM TEST

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
BLUE CLAY	0	16
BROWNISH CLAY WITH LIGHT SAND	16	32
SMALL STONE AND SAND	32	40
WATER AT 37 FEET	40	42

WELL TEST

Bailing | Pumping* | Other

Test rate 14 gpm Duration of test 4 hrs.

Drawdown 15 FEET ft.

Measured from: top of casing | ground level | Other

Static Level (depth to water) 7 ft. Date: 5-30-98

Quality (clear, cloudy, taste, odor)

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump SUBMERSIBLE Capacity 10 gpm

Pump set at 32 ft.

Pump installed by KIM TERRY

WELL LOCATION

Location of well in State Plane coordinates, if available:

Zone x y

Elevation of well ft./m. Datum plain: NAD27 NAD83

Source of coordinates: GPS | Survey | Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.



*(If additional space is needed to complete well log, use next consecutively numbered form.)

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm TERRY WATERWELL DRILLING

Address 9680 NEW SALEM RD

City, State, Zip PLEASANTVILLE OHIO

Signed Kim M Terry

Date 7-13-98

ODH Registration Number 1302

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy