DNR 7802.94
TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Divison of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

823604
Permit Number 3604

COUNTY Mahoning TOWNSHIP Beaver SECTION/LOT No. (Circle One)

OWNER/BUILDER (Circle One or Both) Mike Skripac (First / Last) PROPERTY ADDRESS (Address of well location) 1600 So. Lisbon Rd. (Number / Street) North Lima (City) 44452 (Zip Code + 4)

LOCATION OF PROPERTY

CONSTRUCTION DETAILS

CASING *(Length below grade) Borehole Diameter 6 in.

[1] Diameter 6 in. Length* 47 ft. Wall Thickness .188 in.

[2] Diameter ____ in. Length* ____ ft. Wall Thickness ____ in.

Type: [1][2] Steel [1][2] Galv. [1][2] PVC [1][2] Other

Joints: [1][2] Threaded [1][2] Welded [1][2] Solvent [1][2] Other

Liner: Length ____ Type ____ Wall Thickness ____ in.

SCREEN

Type (wire wrapped, louvered, etc.) ____ Material ____

Length ____ ft. Diameter ____ in. Slot ____

Set between ____ ft. and ____ ft.

GROUT

Material Envirosplug Volume used 50#

Method of installation manual

Depth: placed from 20 ft. to 10 ft.

GRAVEL PACK (Filter Pack)

Material ____ Volume used ____

Method of installation ____

Depth: placed from ____ ft. to ____ ft.

Pitless Device ☐ Adapter ☐ Preassembled unit

Use of Well Home

☐ Rotary ☑ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other

Date of Completion 8/6/96

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Clay & Sand	0	47
Sandstone	47	58
Limestone	58	59
Coal	59	60
Wh shale	60	64
Limestone	64	66
Coal	66	67
Sandy shale (20 GPM)	67	87
Shale	87	90

20 GPM @ 87'

*(If additional space is needed to complete well log, use next consecutively numbered form.)

WELL TEST

☑ Bailing ☐ Pumping* ☐ Other

Test rate 20 gpm Duration of test 2 hrs.

Drawdown 45 ft.

Measured from: ☐ top of casing ☑ ground level ☐ Other

Static Level (depth to water) 10 ft. Date: 8/6/96

Quality (clear, cloudy, taste, odor)

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump BP sub Capacity 10 gpm

Pump set at 85' ft.

Pump installed by Berry

WELL LOCATION

Location of well in State Plane coordinates, if available:

Zone ____ x ____ y ____

Elevation of well ____ ft./m. Datum plain: ☐ NAD27 ☐ NAD83

Source of coordinates: ☐ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.



I hereby certify the information given is accurate and correct to the best of my knowledge.

Signed Gary A. Berry

Date 8/9/96

ODH Registration Number 1362

Drilling Firm BERRY WELL DRILLING

Address P.O. BOX 217

City, State, Zip PETERSBURG, OH 44454

5049

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy