

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

Permit Number 00-030

COUNTY Fairfield

TOWNSHIP Richmond

SECTION/LOT No.
(Circle One)

OWNER/BUILDER WALTER SHEETS
(Circle One or Both) First

PROPERTY ADDRESS 6515 Cincinnati
(Address of well location) Number 3900 the N. Street

City

LOCATION OF PROPERTY App 3 miles west of West Rushville on St. Rt. 22 42130
Zip Code +4

CONSTRUCTION DETAILS

CASING (Length below grade)		Borehole Diameter		7 in.	
1. Diameter	7 in.	Length	30 ft.	Wall Thickness	4/8 in.
2. Diameter		Length		Wall Thickness	
Type:	☒ Steel	☒ Galv.	☐ PVC	☐ Other	
Joints:	☐ Threaded	☒ Welded	☐ Solvent	☐ Other	
Liner:	Length 60	Type PVC	Wall Thickness 4/8 in.		
SCREEN 5" SLOTTED 30-55'					
Type (wire wrapped, louvered, etc.)			Material		
Length	ft.	Diameter	in.		
Set between	ft. and	ft.	Slot		
GROUT					
Material		Box 101T		Volume used 0.25 cu.	
Method of installation		Poured			
Depth: placed from		0		ft. to 30	
GRAVEL PACK (Filter Pack)					
Material				Volume used	
Method of installation					
Depth: placed from				ft. to	
Pitless Device ☐ Adapter ☐ Preassembled unit					
Use of Well					
☐ Rotary		☒ Cable		☐ Augered ☐ Driven ☐ Dug ☐ Other	
Date of Completion		11-25-00			

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

Top Soil	0	2
Yellow Shale	2	10
Yellow Clay	10	12
Brown Shale	12	20
Gray Shale	20	35
Brown Sand	35	40
Gray Shale	40	60

T-D 60'
WATER AT 25'
10 GPM.

WELL TEST

☒ Bailing ☐ Pumping* ☐ Other _____
 Test rate 10 gpm Duration of test 4 hrs
 Drawdown 40' ft
 Measured from: ☐ top of casing ☒ ground level ☐ Other _____
 Static Level (depth to water) 25' ft. Date: 8-4-00
 Quality (clear, cloudy, taste, odor) _____

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump _____ Capacity _____ gpm
Pump set at _____ ft.
Pump installed by _____

WELL LOCATION

Location of well in State Plane coordinates, if available:
 Zone 39 x 39 y 39
 Elevation of well 250 ft./m. Datum plain: ☐ NAD27 ☐ NAD83
 Source of coordinates: ☒ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.

North

West

A hand-drawn map showing a horizontal line representing a road. On the left side of the line, the text "St. Pt. 22" is written. On the right side, "W. Rushville" is written. Below the line, there are two vertical lines extending downwards. The left vertical line is labeled "School" and has a small tick mark. The right vertical line is labeled "400'" and has a small circle at its base. To the right of the "400'" line, the text "with 2.5 to" is written. At the far right end of the horizontal line, the word "East" is written vertically.

South

*(If additional space is needed to complete well log, use next consecutively numbered form.)

I hereby certify the information given is accurate and correct to the best of my knowledge

Drilling Firm Perry Allen Weston Well Drilling

Signed by all

Address 3559 Old Sound Rd.

Date 11-25-00

City, Stat Zip *New London, Conn*

ODJ Registration Number 1360

Completion of this form is required by section 11-105, Ohio Revised Code within 30 days after completion of drilling.

ORIGINAL COPY TO: ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224