

DNR 7802 9-1
TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

826152

Permit Number

97-33

COUNTY

HAROLD

TOWNSHIP

ROUNDHEAD

SECTION/LOT No.

(Circle One)

OWNER/BUILDER

(Circle One or Both)

BRADLEY

PROPERTY ADDRESS

(Address on well location)

13801 Twp Rd. 25N.

Number

Street

City

LOCATION OF PROPERTY

Zip Code

CONSTRUCTION DETAILS

CASING (Length below grade)		Borehole Diameter 5 7/8 in.		GROUT	
1" Diameter 6 in.	Length* 99 ft.	Wall Thickness	in.	Material	Volume used
2" Diameter	Length*	Wall Thickness	in.	Method of installation	
Type: ☒ Steel	☒ Galv.	☐ PVC	☐	Depth: placed from	ft. to
☐ Joints: ☒ Threaded	☐ Welded	☐ Solvent	☐	GRAVEL PACK (Filter Pack)	
				Material	Volume used
				Method of installation	
Liner: Length	Type	Wall Thickness	in.	Depth: placed from	ft. to
SCREEN				Pitless Device	☐ Adapter ☐ Preassembled unit
Type (wire wrapped, louvered, etc.)				Material	
Length				ft.	Diameter
Set between				ft.	and
ft.				Slot	
WELL LOG*				WELL TEST	

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation.
sandstone, shale, limestone, gravel, clay, sand, etc.

RED CLAY
GRAY CLAY
SAND
GRAVEL + SAND

From	To
0	20
20	80
80	86
86	99

☒ Bailing	☒ Pumping*	Other
Test rate 20 gpm	Duration of test 2 hrs.	
Drawdown 10 ft.		
Measured from: ☒ top of casing	☐ ground level	Other
Static Level (depth to water) 50 ft.	Date:	
Quality (clear, cloudy, taste, odor) CLEAR		


*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump	Capacity	gpm
Pump set at		ft.
Pump installed by		

WELL LOCATION

Location of well in State Plane coordinates, if available:			
Zone	x	y	
Elevation of well	ft./m	Datum plain:	NAD27 ☐ NAD83 ☐
Source of coordinates:	IGPS	Survey	Other
Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.			



(If additional space is needed to complete well log, use next consecutively numbered form.)

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm

NW OHIO WELL DRILLING

Address

1589 N. THAYER RD.

City, State, Zip

Lima OH. 45801

Signed

Sgt. W. W. W.

Date

2-3-98

ODH Registration Number

2298

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy