

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

826342

Permit Number 7183

COUNTY **STARK**

TOWNSHIP **LEXINGTON**

SECTION/LOT No. **27**
(Circle One)

OWNER/BUILDER **SHER MOHAMMED**
(Circle One or Both) First Last

PROPERTY ADDRESS **10929**
(Address of well location) Number

Street **HELMAN** City **ALLIANCE**

LOCATION OF PROPERTY **N. OF BEESON ST., W. SIDE**

Zip Code **44601**

CONSTRUCTION DETAILS

CASING *(Length below grade)		Borehole Diameter 7 3/4 in.		GROUT	
1" Diameter 5 in.	Length* 62 ft.	Wall Thickness 5/16 in.	Material BENSEAL/1/2" mud	Volume used 65 GAL	
2" Diameter	Length*	Wall Thickness	Method of installation PRESSURE GROUT		
Type: 1. Steel 2. Galv. ☒ PVC		1. 2. Other	Depth: placed from 62 ft. to SURFACE ft.		
Joints: 1. Threaded 2. Welded ☒ Solvent		1. 2. Other	GRAVEL PACK (Filter Pack)		
Liner: Length Type Wall Thickness			Material Volume used		
SCREEN					
Type (wire wrapped, louvered, etc.)		Material			
Length ft.	Diameter				
Set between ft. and	ft.	Slot			
		Pitless Device ☒ Adapter ☐ Preassembled unit			
		Use of Well DOMESTIC			
		in. ☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Dug ☒ Other Air			
		Date of Completion 9/16/97			

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
BR SANDY CLAY	0	12
B GRAY CLAY	12	19
BOULDERS	19	22
SHALE SOFT	22	48
COAL & FIRE CLAY	48	56
LT. GR. SOFT SHALE	56	58
DK GR. SHALE	58	84
SLATE W/ COAL STREAKS	84	89
GR. SANDSTONE	89	93
LT GR SANDY SHALE	93	109
T.D.	109	

water 102

WELL TEST

Bailing	Pumping*	Other
Test rate 10 gpm	Duration of test	hrs.
Drawdown		ft.
Measured from: 1. top of casing ☒ ground level 2. Other		
Static Level (depth to water) 30 ft.	Date: 9/22/97	
Quality (clear) cloudy, taste, odor		

*(Attach a copy of the pumping test record, per section 1521.05, ORC)


PUMP

Type of pump 2 1/2" P. SUB.	Capacity 10 gpm
Pump set at 80	ft.
Pump installed by DAVIDSON	

WELL LOCATION

Location of well in State Plane coordinates, if available:	
Zone x	y
Elevation of well ft./m.	Datum plain: NAD27 INAD83
Source of coordinates: ☐ GPS ☐ Survey ☐ Other	

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.



*(If additional space is needed to complete well log, use next consecutively numbered form.)

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm **DAVIDSON WELL DRILLING**
Address **360 BEECHWOOD AVE**
City, State, Zip **ALLIANCE, OH 44601**

Signed **John, Mike & Craig Davidson**
Date **9/27/97**
ODH Registration Number **586**