

# WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources  
Division of Water, 1939 Fountain Square Drive  
Columbus, Ohio 43224 Phone (614) 265-6739

826818

Permit Number 2844/181903

COUNTY Stark TOWNSHIP Nimishillen SECTION/LOT No. \_\_\_\_\_  
(Circle One)  
OWNER/BUILDER Bruce Tindlin PROPERTY ADDRESS 3801 Beck Rd Louisville  
(Circle One or Both) First Last Number Street City  
LOCATION OF PROPERTY 1/10 mile S of Louisville Rd on W side of Beck Rd Zip Code + 4 44641

## CONSTRUCTION DETAILS

CASING (Length below grade) Borehole Diameter 5 5/8 in.  
1 Diameter 5 5/8 in. Length 69 ft. Wall Thickness 0.258 in. Material Bentonite Volume used 100 lb  
2 Diameter \_\_\_\_\_ in. Length \_\_\_\_\_ ft. Wall Thickness \_\_\_\_\_ in. Method of installation Dry - Vibration  
Type: ☒ Steel ☐ Galv. ☐ PVC ☐ Other \_\_\_\_\_  
Joints: ☒ Threaded ☐ Welded ☐ Solvent ☐ Other \_\_\_\_\_  
Liner: Length \_\_\_\_\_ Type \_\_\_\_\_ Wall Thickness \_\_\_\_\_ in. Depth: placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
SCREEN  
Type (wire wrapped, louvered, etc.) \_\_\_\_\_ Material \_\_\_\_\_  
Length \_\_\_\_\_ ft. Diameter \_\_\_\_\_ in. ☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other \_\_\_\_\_  
Set between \_\_\_\_\_ ft. and \_\_\_\_\_ ft. Slot \_\_\_\_\_ Date of Completion Mar 14, 96

## WELL LOG\*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:  
sandstone, shale, limestone, gravel, clay, sand, etc.

| From | To |
|------|----|
| 0    | 66 |
| 66   | 84 |

Brown Sand, gravel, clay  
Brown Sandstone

Water at 70-84

## WELL TEST

☒ Bailing ☐ Pumping\* ☐ Other \_\_\_\_\_  
Test rate 10 gpm Duration of test 1 hrs.  
Drawdown 15 ft.  
Measured from: ☐ top of casing ☒ ground level ☐ Other \_\_\_\_\_  
Static Level (depth to water) 28 ft. Date: Mar 14, 96  
Quality (clear, cloudy, taste, odor) \_\_\_\_\_

\*(Attach a copy of the pumping test record, per section 1521.05, ORC)


## PUMP

Type of pump \_\_\_\_\_ Capacity \_\_\_\_\_ gpm  
Pump set at \_\_\_\_\_ ft.  
Pump installed by Unknown

## WELL LOCATION

Location of well in State Plane coordinates, if available:  
Zone \_\_\_\_\_ x \_\_\_\_\_ y \_\_\_\_\_  
Elevation of well \_\_\_\_\_ ft./m. Datum plain: ☐ NAD27 ☐ NAD83  
Source of coordinates: ☐ GPS ☐ Survey ☐ Other \_\_\_\_\_

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.



(If additional space is needed to complete well log, use next consecutively numbered form.)

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm N. L. Smith Well Drilling Co  
Address 9268 Rockland Ave NW  
City, State, Zip Marietta, OH 44647

Signed N. L. Smith  
Date Mar 23, 96  
ODH Registration Number L875

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy