

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

827011

Permit Number 182 642

COUNTY SUMMIT

TOWNSHIP RICHFIELD

SECTION/LOT No.
(Circle One)

OWNER/BUILDER DAVID A COLNAR
(Circle One or Both) First Last

PROPERTY ADDRESS 3941 Brecksville Rd
(Address of well location) Number Street City

44286
Zip Code + 4

LOCATION OF PROPERTY

CONSTRUCTION DETAILS

CASING (Length below grade) Borehole Diameter <u>5</u> in.		GROUT	
☒ Diameter <u>3</u> in.	Length <u>45</u> ft.	Wall Thickness <u>15 LB</u> in.	Material <u> </u> Volume used <u> </u>
☐ Diameter <u> </u> in.	Length <u> </u> ft.	Wall Thickness <u> </u> in.	Method of installation <u> </u>
Type: ☒ Steel ☐ Galv. ☐ PVC	☐ Galv. ☐ PVC	☐ Other <u> </u>	Depth: placed from <u> </u> ft. to <u> </u> ft.
Joints: ☒ Threaded ☐ Welded ☐ Solvent	☐ Threaded ☐ Welded ☐ Solvent	☐ Other <u> </u>	GRAVEL PACK (Filter Pack)
Liner: Length <u> </u> Type <u> </u>	Wall Thickness <u> </u> in.	Depth: placed from <u> </u> ft. to <u> </u> ft.	Material <u> </u> Volume used <u> </u>
SCREEN		Pitless Device ☒ Adapter ☐ Preassembled unit	
Type (wire wrapped, louvered, etc.) <u> </u> Material <u> </u>		Use of Well <u>House</u>	
Length <u> </u> ft. Diameter <u> </u> in.		☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other <u> </u>	
Set between <u> </u> ft. and <u> </u> ft. Slot <u> </u>		Date of Completion <u>6-13-96</u>	

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

From To

YELLOW CLAY
BLUE CLAY
SHALE

0 8
8 45
45 56

WELL TEST

☒ Bailing	☐ Pumping*	☐ Other <u> </u>
Test rate <u>10</u> gpm	Duration of test <u>1/2</u> hrs.	
Drawdown <u>9</u> ft.		
Measured from: ☐ top of casing ☒ ground level ☐ Other <u> </u>		
Static Level (depth to water) <u> </u> ft. Date: <u> </u>		
Quality (clear, cloudy, taste, odor) <u>CLEAR</u>		

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump <u>JGT</u>	Capacity <u>6</u> gpm
Pump set at <u>30</u> ft.	
Pump installed by <u>DAVID A COLNAR</u>	

WELL LOCATION


Location of well in State Plane coordinates, if available:

Zone x y

Elevation of well ft./m. Datum plain: ☐ NAD27 ☐ NAD83

Source of coordinates: ☐ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.



(If additional space is needed to complete well log, use next consecutively numbered form.)

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Philip Urban

Signed Philip Urban

Address 4683 Quirk Road

Date June 13-96

City, State, Zip PELIN OHIO 44264

ODH Registration Number 494

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's conv. Pink - Driller's conv. Green - Local Health Dept. conv.