

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

827400

Permit Number 357

COUNTY Jackson

TOWNSHIP Washington

SECTION/LOT No.
(Circle One)

OWNER/BUILDER Paul Tedrow
(Circle One or Both) First Last

PROPERTY ADDRESS 893 Lesmil Rd. Wellston
(Address of well location) Number Street City

LOCATION OF PROPERTY about 2 miles from SR-93 on Lesmil Rd. Zip Code + 4 45692

CONSTRUCTION DETAILS

CASING *(Length below grade) Borehole Diameter 3 3/8 in.
[1] Diameter 6 in. Length* 25 ft. Wall Thickness
[2] Diameter. in. Length* ft. Wall Thickness
Type: [1] Steel [1] Galv. [1] PVC [1]
[2] Steel [2] Galv. [2] PVC [2]
Joints: [1] Threaded [1] Welded [1] Solvent [1]
[2] Threaded [2] Welded [2] Solvent [2]
Liner: Length Type Wall Thickness

SCREEN

Type (wire wrapped, louvered, etc.) Material
Length ft. Diameter
Set between ft. and ft. Slot

GROUT Drill Cuttings
in. Material Granular Bedrock Volume used 30 lbs
in. Method of installation Pour
Depth: placed from 25 ft. to Surface ft.
GRAVEL PACK (Filter Pack)
Material Volume used
Method of installation
Depth: placed from ft. to ft.
Pitless Device ☒ Adapter ☐ Preassembled unit
Use of Well Home
in. ☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other
Date of Completion 10-23-97

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Clay	0	15
Gray Shale	15	20
Gray Sandy Shale	20	75
Gray Sandy Shale w/ Shale Bedrock	75	119
Silica Gravel w/ Shale	119	130
White Sand w/ Gravel	130	144
Coal	144	145
Gray Sandy Shale ?	145	146
water	130'	

WELL TEST

Bailing ☐ Pumping* ☒ Other air Blowing
Test rate 10 ? gpm Duration of test hrs.
Drawdown ft.
Measured from: ☐ top of casing ☒ ground level ☐ Other
Static Level (depth to water) 76 ft. Date: 10-22-97
Quality (clear, cloudy, taste, odor) Clear

*(Attach a copy of the pumping test record, per section 1521.05, ORC)


PUMP

Type of pump Sub. Capacity 10 gpm
Pump set at 140' ft.
Pump installed by Randolph Hall

WELL LOCATION

Location of well in State Plane coordinates, if available:
Zone x y
Elevation of well ft./m. Datum plain: ☐ NAD27 ☐ NAD83
Source of coordinates: ☐ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.



*(If additional space is needed to complete well log, use next consecutively numbered form.)

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Halt's Well Drilling
Address 23957 SR-93 S
City, State, Zip Wellston, Oh. 45692

Signed Randolph Hall
Date 10-23-97
ODH Registration Number 403