

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

Permit Number 197326

COUNTY Tuscarawas TOWNSHIP Sugar Creek SECTION/LOT No. _____
(Circle One)

☒ OWNER/BUILDER Russell Angel PROPERTY ADDRESS 7021 Angel Rd. N.W. Dundee
(Circle One or Both) First Last (Address of well location) Number Street City

LOCATION OF PROPERTY Same Zip Code 44624

CONSTRUCTION DETAILS

CASING (Length below grade) Borehole Diameter 8 in.
 ① Diameter 6 in. Length 80 ft. Wall Thickness 1/4 in. Material 1/4" Hole Plug Pellets Volume used 800 lbs
 ② Diameter 4 in. Length 167 ft. Wall Thickness 1/4 in. Method of installation Pour - Dry
 Type: ① Steel ① Galv. ① PVC ① _____
 ② _____ ② _____ ② _____ ② _____
 Joints: ① Threaded ① Welded ① Solvent ① _____
 ② _____ ② _____ ② _____ ② _____
 Liner: Length 100' Type PVC Wall Thickness 1/4 in. Depth: placed from _____ ft. to _____ ft.
SCREEN
 Type (wire wrapped, louvered, etc.) _____ Material _____
 Length _____ ft. Diameter _____ in.
 Set between _____ ft. and _____ ft. Slot _____
GROUT
 Material _____ Volume used _____
 Method of installation _____
 Depth: placed from _____ ft. to _____ ft.
GRAVEL PACK (Filter Pack)
 Material _____ Volume used _____
 Method of installation _____
 Depth: placed from _____ ft. to _____ ft.
 Pitless Device ☐ Adapter ☐ Preassembled unit
 Use of Well ☒ Private Home
☒ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
 Date of Completion 3-7-97

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Reclaim Spoil	0	35'
Dark Shale	35	80'
Sandstone (Water)	80	105
Dark Shale	105	115
Limestone	115	117
Coal	117	119
Light Gray Shale (Some Sandy)	119	140
Dark Plastic Shale	140	165
Hard Fine Sandstone	165	175
Dark Plastic Shale	175	200
Limestone	200	205
Light Gray Shale	205	225
Sandy Shale	225	235
Green Shale (Cave)	235	238
Hard Gray Shale	238	262
Hard Shale + Sandrock	262	275
Fine Sand rock	275	288
Course Sandrock (W)	288	315

WELL TEST

☐ Bailing ☒ Pumping* ☐ Other _____
 Test rate 14 gpm Duration of test 96 hrs.
 Drawdown 12' (248") ft.
 Measured from: ☐ top of casing ☐ ground level ☐ Other _____
 Static Level (depth to water) 235 ft. Date: 3-2-97
 Quality (clear, cloudy, taste, odor) End of Test: Light
Odor, Clear, P.H. 6.9, 3 Part Iron
 *(Attach a copy of the pumping test record, per section 1521.05, ORC) 32

PUMP

Type of pump 1 in sub. Capacity 8 @ 55 Hrs gpm
Pump set at 240' on 255' 1" - 5 in # 20 ft.
Pump installed by Bloo Drilling

WELL LOCATION

Location of well in State Plane coordinates, if available:
 Zone _____ x _____ y _____
 Elevation of well _____ ft./m. Datum plain: ☐ NAD27 ☐ NAD83
 Source of coordinates: ☐ GPS ☐ Survey ☐ Other _____
 Sketch a map showing distance well lies from numbered state highways,
 street intersections, county roads, buildings or other notable landmarks.

A hand-drawn map showing a road network. At the top is a point labeled "Dundee North". A line labeled "State # 516" runs from Dundee North towards the right. A line labeled "Co. # 73" runs from Dundee North towards the bottom left. At the bottom left is a point labeled "Barnes Mills". A line labeled "7438" runs vertically from the "Co. # 73" line. A line labeled "7365" runs diagonally from the "7438" line towards the right. At the bottom right is a point labeled "Winfield". The map is oriented with "West" on the left, "East" on the right, and "South" at the bottom. There is a small, illegible label near the intersection of "7438" and "7365".

(If additional space is needed to complete well log, use next consecutively numbered form.)

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Bloom Ex. & Drilling Signed Thomas Parker
Address 11072 Shetler Rd. NW Date 3-20-97
City, State, Zip Bolivar Ohio 44612 ODH Registration Number 482

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy