

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

Permit Number 19735

COUNTY TUSCARAWAS TOWNSHIP LAWRENCE SECTION/LOT No. 9019
(Circle One)

OWNER/BUILDER George Billiter PROPERTY ADDRESS 9019 Fort Laurens Rd., Bolivar, O.
(Circle One or Both) First Last (Address of well location) Number Street City

LOCATION OF PROPERTY Same 44612
Zip Code + 4

CONSTRUCTION DETAILS

CASING (Length below grade) Borehole Diameter <u>8</u> in.		GROUT <u>Ben Seal Pills</u> <u>5 Gal Bucket</u>	
[1] Diameter <u>5 7/8</u> in.	Length* <u>297</u> ft.	Wall Thickness <u>1/4</u> in.	Material <u>Fire Clay</u> Volume used <u>3000 Lb</u>
[2] Diameter _____ in.	Length* _____ ft.	Wall Thickness _____ in.	Method of installation <u>Pumped Thru Tremie</u>
Type: [1] <u>Steel</u> [2] <u>Galv.</u> [3] <u>PVC</u>	[1] _____ [2] <u>Other</u>	Depth: placed from <u>297'</u> ft. to <u>Grade</u> ft.	GRAVEL PACK (Filter Pack)
Joints: [1] <u>Threaded</u> [2] <u>Welded</u> [3] <u>Solvent</u>	[1] _____ [2] <u>Other</u>	Material _____ Volume used _____	Method of installation _____
Liner: Length _____ Type _____	Wall Thickness _____ in.	Depth: placed from _____ ft. to _____ ft.	Pitless Device ☒ Adapter ☐ Preassembled unit
SCREEN		Use of Well <u>Residential Home</u>	
Type (wire wrapped, louvered, etc.) _____	Material _____	☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____	
Length _____ ft.	Diameter _____ in.	Date of Completion <u>11-18-97</u>	
Set between _____ ft. and _____ ft.	Slot _____		

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.	From	To
Clay Subsoil	0	8'
Brown Sandrock (W) 16PM	8'	38'
Gray Shale	38'	58'
Limestone	58'	60'
Gray Shale	60'	85'
Plastic Shale	85'	96'
Limestone	96'	98'
Hard Black Shale	98'	101'
Plastic Shale	101'	174'
Limestone	174'	178'
Plastic Shale	178'	250'
Sandrock (W) Iron	250'	260'
Plastic Shale	260'	280'
Gray Shale	280'	286'
Gray Sandy Shale	286'	328'
Sand Rock (W)	328'	350'

WELL TEST

☐ Bailing ☒ Pumping* ☐ Other _____
 Test rate 20 gpm Duration of test 72 hrs.
 Drawdown 100' - Work Level - 2.55' ft.
 Measured from: ☐ top of casing ☒ ground level ☐ Other _____
 Static Level (depth to water) 15.5 ft. Date: _____
 Quality (clear, cloudy, taste, odor) 0.5 Iron, 150 TD
11 Grain Hard pH: Neutral
 *(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Submersible Capacity 9 @ 50lb @ 250' gpm
Pump set at On 280' Sch #80 Plastic ft.
Pump installed by Blac Drilling

WELL LOCATION

Location of well in State Plane coordinates, if available:

Zone _____ x _____ y _____

Elevation of well _____ ft./m. Datum plain: ☐ NAD27 ☐ NAD83

Source of coordinates: ☐ GPS ☐ Survey ☐ Other _____

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.

Hand-drawn map of the area around Strassburg, Missouri. The map shows a road running North-South, with "Bellevue North" at the top and "Strassburg" at the bottom. A road branches off to the West, labeled "Co. 102 (2 mi.)". A road branches off to the East, labeled "Inter #1". A "House" is marked with a square and "Well" is marked with a circle. A shaded area is labeled "Septic".

*(If additional space is needed to complete well log, use next consecutively numbered form.)

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Bloo Drilling
Address 11072 Shetler Rd. N.W.
City, State, Zip Bolivar Ohio 44612

Signed Thomas Parker
Date 1-18-97

ODH Registration Number

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy