

WELL LOG AND DRILLING REPORT

830480

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

Permit Number 192539

COUNTY Tuscarawas TOWNSHIP Oxford SECTION/LOT No. _____
(Circle One)

OWNER/BUILDER Steven Brode PROPERTY ADDRESS 15575 Foreman Club Rd Newcomerstown
(Circle One or Both) First Last (Address of well location) Number Street City

LOCATION OF PROPERTY 15575 Foreman Club Rd Newcomerstown, Ohio Zip Code 43832

CONSTRUCTION DETAILS

CASING (Length below grade) Borehole Diameter 7 in.
① Diameter 7 in. Length 54 ft. Wall Thickness _____ in. Material Benseal + Clay Volume used 500 lb.
② Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation Cable tool
Type: ☒ Steel ☐ Galv. ☐ PVC ☐ Other _____
Joints: ☒ Threaded ☐ Welded ☐ Solvent ☐ Other _____
Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.
SCREEN
Type (wire wrapped, louvered, etc.) _____ Material _____
Length _____ ft. Diameter _____ in.
Set between _____ ft. and _____ ft. Slot _____

GROUT
Material Benseal + Clay Volume used 500 lb.
Method of installation Cable tool
Depth: placed from _____ ft. to _____ ft.
GRAVEL PACK (Filter Pack)
Material _____ Volume used _____
Method of installation _____
Depth: placed from _____ ft. to _____ ft.
Pitless Device ☒ Adapter ☐ Preassembled unit
Use of Well DOMESTIC
☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Date of Completion Sept. 11, 1996

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.
Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Brown Sandy Shale	0	12
Light Shale	12	22
DARK Shale	22	30
LIGHT Shale	30	39
GRAY SAND STONE	39	42
LIGHT Shale	42	54
DARK Shale	54	68
LIGHT SANDSTONE	68	70
DARK Shale	70	76
LIGHT Shale	76	83
GRAY SANDSTONE	83	84
Water at 68 ft.		

WELL TEST


☒ Bailing ☐ Pumping* ☐ Other _____
Test rate 12 gpm Duration of test 1 hrs.
Drawdown 68 ft.
Measured from: ☐ top of casing ☒ ground level ☐ Other _____
Static Level (depth to water) 22 ft. Date: Sept 12, 1996
Quality (clear, cloudy, taste, odor) CLOUDY
*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Sita-Rite Capacity 7 gpm
Pump set at 74 ft.
Pump installed by Harry Glen England JR.

WELL LOCATION

Location of well in State Plane coordinates, if available:
Zone _____ x _____ y _____
Elevation of well _____ ft./m. Datum plain: ☐ NAD27 ☐ NAD83
Source of coordinates: ☐ GPS ☐ Survey ☐ Other _____
Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.



(If additional space is needed to complete well log use next consecutively numbered form.) I hereby certify the information given is accurate and correct to the best of my knowledge.
Drilling Firm England DRILLING Signed Harry Glen England Jr
Address 6806 Kings Ridge Rd Date Sept. 12, 1996
City, State, Zip Newcomerstown, Ohio 43832 ODH Registration Number 1751