

WELL LOG AND DRILLING REPORT

832744

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

Permit Number 11

COUNTY Guernsey TOWNSHIP Oxford SECTION/LOT No. _____
(Circle One)
OWNER/BUILDER Frank Dickey PROPERTY ADDRESS 64490 Rosedale Rd Salesville
(Circle One or Both) First Last (Address of well location) Number Street City
LOCATION OF PROPERTY Salesville 43178
Zip Code +4

CONSTRUCTION DETAILS

CASING (Length below grade) Borehole Diameter 8 in.
1) Diameter 8 in. Length* 100 ft. Wall Thickness SDR21 in. Material GROUT Volume used 400 LB
2) Diameter 8 in. Length* 30 ft. Wall Thickness SDR21 in. Method of installation poured
Type: 1) Steel 1) Galv. ☒ PVC 1) _____
2) _____ 2) _____ 2) Other _____
Joints: 1) Threaded 1) Welded ☒ Solvent 1) _____
2) _____ 2) _____ 2) Other _____
Liner: Length 100 Type PVC Wall Thickness SDR24
Depth: placed from 105 ft. to 5 ft.
SCREEN
Type (wire wrapped, louvered, etc.) NA Material _____
Length _____ ft. Diameter _____ in.
Set between _____ ft. and _____ ft. Slot _____
GRAVEL PACK (Filter Pack)
Material pea gravel Volume used 1 ton
Method of installation poured
Depth: placed from _____ ft. to _____ ft.
Pitless Device ☒ Adapter ☐ Preassembled unit
Use of Well domestic
in. 1) Rotary ☒ Cable ☐ Augered 1) Driven ☐ Dug 1) Other _____
Date of Completion 8-20-01

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Topsoil	0	1'
yellow shale	1	10
sand rock	10	26
gray shale	26	38
blue rock	38	50
red shale	50	55
black shale	55	68
coal	68	70
blue rock	* 70	80
shale	80	100
blue rock	100	105

* water 70'

WELL TEST

☒ Bailing ☐ Pumping* ☐ Other _____
Test rate 3 gpm Duration of test 8 hrs.
Drawdown 100 ft.
Measured from: ☐ top of casing ☒ ground level ☐ Other _____
Static Level (depth to water) 45 ft. Date: 8-20-01
Quality (clear, cloudy, taste, odor) clear
no taste, no odor
*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Submersible Capacity 10 gpm
Pump set at 100 ft.
Pump installed by M. Dickey

WELL LOCATION

Location of well in State Plane coordinates, if available:
Zone _____ x _____ y _____
Elevation of well _____ ft./m. Datum plain: ☐ NAD27 ☐ NAD83
Source of coordinates: ☐ GPS ☐ Survey ☐ Other _____

Sketch a map showing distance well lies from numbered state highways,
street intersections, county roads, buildings or other notable landmarks.

200+ North
drive
20' @ well
118'
☐ mobile Home
West East
Rosedale Rd
South

*(If additional space is needed to complete well log, use next consecutively numbered form.) I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Dam Water Well Signed Monroe P Dickey
Address 58021 Buffalo Mine Rd Date 12-18-01
City, State, Zip Seneecville, OH 43780 ODH Registration Number 07015