

COUNTY FAIRFIELD TOWNSHIP LIBERTY SECTION/LOT No. _____
(Circle One)

OWNER/BUILDER THOMAS/MAIBAUM PROPERTY ADDRESS 12533 SAYLOR A BALTIMORE
(Circle One or Both) First Last (Address of well location) Number Street City

LOCATION OF PROPERTY SAME Zip Code + 4

CONSTRUCTION DETAILS

CASING (Length below grade)		Borehole Diameter		GROUT	
① Diameter	5 1/2 in.	Length	25 ft.	Material	BENTONITE
② Diameter		Wall Thickness	250 in.	Volume used	50 #
Type:	☒ Steel	☐ Galv.	☐ PVC	Method of installation	DRY DRIVEN
Joints:	☒ Threaded	☐ Welded	☐ Solvent	Depth: placed from	0 ft. to 25 ft.
Liner:	Length	Type	Wall Thickness	GRAVEL PACK (Filter Pack)	
SCREEN				Material	
Type (wire wrapped, louvered, etc.)		Material		Method of installation	
Length	NONE ft.	Diameter		Depth: placed from	
Set between		ft. and		Pitless Device	☒ Adapter ☐ Preassembled unit
		ft.	Slot	Use of Well	RESIDENCE
				☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other	
				Date of Completion	12/5/96

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

Soil color, texture, hardness, and formation. sandstone, shale, limestone, gravel, clay, sand, etc.	From	To
YELLOW CLAY	0	12
GREY SANDY CLAY	12	23
SAND + GRAVEL	23	25

WELL TEST

☐ Bailing ☒ Pumping* ☐ Other _____
 Test rate 10 gpm Duration of test 2 hrs
 Drawdown 5 ft.
 Measured from: ☐ top of casing ☒ ground level ☐ Other _____
 Static Level (depth to water) 9 ft. Date: _____
 Quality (clear, cloudy, taste, odor) CLEAR

*(Attach a copy of the pumping test record, per section 1521.05, ORC)


PUMP

Type of pump SUBMERSIBLE Capacity 10 gpm
Pump set at 22 ft.
Pump installed by PLUMMER & M^c DANNALD

WELL LOCATION

Location of well in State Plane coordinates, if available:
 Zone _____ x _____ y _____
 Elevation of well _____ ft./m. Datum plain: ☐ NAD27 ☐ NAD83
 Source of coordinates: ☐ GPS ☐ Survey ☐ Other _____

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.



*(If additional space is needed to complete well log, use next consecutively numbered form.)

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm PLUNGER & M^CDANNALO

Signed James D Palmer

Address 74 CENTRAL AVE

Date 12/16/96

City, State, Zip WESTERVILLE OH 43081

ODH Registration Number 87

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy