

WELL LOG AND DRILLING REPORT

833075

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

Permit Number

1

COUNTY Monroe TOWNSHIP JACKSON SECTION/LOT No. _____
(Circle One)
OWNER/BUILDER Gravel Hill Baptist PROPERTY ADDRESS 33125 SR 800 New Martins, OH 45767
(Circle One or Both) First Last (Address of well location) Number Street City Zip Code + 4
LOCATION OF PROPERTY 1/4 mile W SR 800 AT Fly, from SR 7

CONSTRUCTION DETAILS

CASING (Length below grade) Borehole Diameter _____ in.
[1] Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Material Benz Seal Volume used 200 lbs.
[2] Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of Installation pour in
Type: [1] Steel [1] Galv. [1] PVC [1] _____
[2] Other _____
Joints: [1] Threaded [1] Welded [1] Solvent [1] _____
[2] Other _____
Liner: Length 112' Type PE Wall Thickness 1/2 in. Depth: placed from 40' ft. to 10' ft.
SCREEN
Type (wire wrapped, louvered, etc.) _____ Material _____
Length _____ ft. Diameter _____ in.
Set between _____ ft. and _____ ft. Slot _____
GROUT
[1] Pitless Device [1] Adapter [1] Preassembled unit
Use of Well Home - Pictus House
[1] Rotary [1] Cable [1] Augered [1] Driven [1] Dug [1] Other _____
Date of Completion 1-31-96

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

From To

ALTATION

Clear out -

added 112' x 6"

Liner casing

Used 6" x 10" shale packer

TO SEAL,

2 bags Benz Seal

6" x 6"

2 bags Benz Seal hole plug

TO MOUT OLD METAL Casing

1030 lbs. - gravel 49.

WELL TEST

[1] Bailing [1] Pumping [1] Other _____
Test rate 15 gpm Duration of test 24 hrs.
Drawdown 62' ft.
Measured from: [1] top of casing [1] ground level [1] Other _____
Static Level (depth to water) 57' ft. Date: 1-30-96
Quality (clear, cloudy, taste, odor) water has brown -
SAID


*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Diaphragm Capacity 10 gpm
Pump set at 102' in TREN ft.
Pump installed by Charles Hall

WELL LOCATION

Location of well in State Plane coordinates, if available:
Zone _____ x _____ y _____
Elevation of well _____ ft./m. Datum plain: [1] NAD27 [1] NAD83
Source of coordinates: [1] GPS [1] Survey [1] Other _____
Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.



(If additional space is needed to complete well log, use next consecutively numbered form.) I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm HALL WATER WELL DRILLING Signed Charles Hall
Address RT 8 Box 153 Date 1-31-96
City, State, Zip Marietta, OH 45750 ODH Registration Number 1500