DNR 7802.94
TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Divison of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

841370

Permit Number 3280

PAGE 1 OF 1

COUNTY LICKING TOWNSHIP WASHINGTON SECTION SECTION/LOT No. (Circle One)

OWNER

OWNER/BUILDER (Circle One or Both) TOM CARON First Last PROPERTY ADDRESS (Address of well location) 8621 RICHARDS RD UTICA OH 43080 Number Street City

LOCATION OF PROPERTY 43080 Zip Code + 4

CONSTRUCTION DETAILS

CASING *(Length below grade) Borehole Diameter 7 7/8 in.

[1] Diameter 5 in. Length* 80 ft. Wall Thickness 1/4 in.

[2] Diameter in. Length* ft. Wall Thickness in.

Type: [1] Steel [2] [1] Galv. [2] [XX] PVC [2] [1] [2] Other

Joints: [1] Threaded [2] [1] Welded [2] [XX] Solvent [2] [1] [2] Other

Liner: Length Type Wall Thickness in.

SCREEN

Type (wire wrapped, louvered, etc.) Material

Length ft. Diameter in.

Set between ft. and ft. Slot

GROUT

Material BENTONITE Volume used 220 LBS

Method of installation TREMIE PIPE

Depth: placed from 0 ft. to 80 ft.

GRAVEL PACK (Filter Pack)

Material Volume used

Method of installation

Depth: placed from ft. to ft.

Pitless Device [XX] Adapter [ ] Preassembled unit

Use of Well HOME

[XX] Rotary [ ] Cable [ ] Augered [ ] Driven [ ] Dug [ ] Other

Date of Completion 07/04/96

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
TOPSOIL	0	2
SOFT BROWN SHALE	2	40
SOFT BROWN SANDSTON	40	50
SOFT YELLOW/BROWN SANDSTONE	50	70
HARD BLUE SANDSTONE	70	80
HARD BLUE/BROWN SANDSTONE	80	140

*(If additional space is needed to complete well log, use next consecutively numbered form.)

WELL TEST

[ ] Bailing [XX] Pumping* [ ] Other

Test rate 12 gpm Duration of test 1 hrs.

Drawdown 0 ft.

Measured from: [XX] top of casing [ ] ground level [ ] Other

Static Level (depth to water) 70 ft. Date: 07/04/96

Quality (clear, cloudy, taste, odor)

CLEAR

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump SUBMERSIBLE Capacity 12 gpm

Pump set at 120 ft.

Pump installed by KEEN WELL & PUMP CO

WELL LOCATION

Location of well in State Plane coordinates, if available:

Zone x y

Elevation of well ft./m. Datum plain: [ ] NAD27 [ ] NAD83

Source of coordinates: [ ] GPS [ ] Survey [ ] Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.



I hereby certify the information given is accurate and correct to the best of my knowledge.

Signed

Date 08/16/96

Drilling Firm KEEN WELL & PUMP CO.

Address 7458 RANGELINE RD.

City, State, Zip MT. VERNON, OH 43050

ODH Registration Number ~~013152~~ 382

5334

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy