

DNR 7802.94
TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

842751

Permit Number

COUNTY Montgomery

TOWNSHIP Madison

SECTION/LOT No.
(Circle One)

OWNER/BUILDER Joe D. Derringer PROPERTY ADDRESS 5376 Wolf Creek Rd. Madison
(Circle One or Both) First Last (Address of well location) Number Street City

LOCATION OF PROPERTY About 1/2 m. E. of Olive Rd. S. Side Zip Code - 4

CONSTRUCTION DETAILS

CASING (Length below grade) Borehole Diameter in. **GROUT**
[1] Diameter 6 in. Length 43 ft. Wall Thickness 1.57 in. Material WY-BEN Volume used 80 LB
[2] Diameter in. Length ft. Wall Thickness in. Method of installation Tap Inset
Type: [1] Steel [1] Galv. [1] PVC [1] Depth: placed from 0 ft. to 25 ft.
[2] Other **GRAVEL PACK** (Filter Pack)
Joints: [1] Threaded [1] Welded [1] Solvent [1] Material Volume used
[2] Other Method of installation
Liner: Length Type Wall Thickness in. Depth: placed from ft. to ft.
SCREEN
Type (wire wrapped, louvered, etc.) Material
Length ft. Diameter in. ☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other
Set between ft. and ft. Slot Date of Completion 9-22-96

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
<u>Soil</u>	<u>0</u>	<u>2</u>
<u>Dry Gravel</u>	<u>2</u>	<u>15</u>
<u>Hard Pan</u>	<u>15</u>	<u>29</u>
<u>Coarse Water Gravel & Sand</u>	<u>29</u>	<u>43</u>
<u>Hard Pan</u>	<u>43</u>	<u>-</u>

WELL TEST

☒ Bailing ☒ Pumping ☐ Other
Test rate 50 gpm Duration of test 6 hrs.
Drawdown 0 ft.
Measured from: ☐ top of casing ☒ ground level ☐ Other
Static Level (depth to water) 14' ft. Date:
Quality (clear, cloudy, taste, odor) Clear

*(Attach a copy of the pumping test record, per section 1521.05, ORC)


PUMP

Type of pump 1/4 HP Capacity 15 GPM gpm
Pump set at 40' ft.
Pump installed by D.E. Derringer

WELL LOCATION

Location of well in State Plane coordinates, if available:
Zone 18 x 18 y
Elevation of well 1136 ft./m. Datum plain: ☐ NAD27 ☐ NAD83
Source of coordinates: ☐ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways,
street intersections, county roads, buildings or other notable landmarks.



(If additional space is needed to complete well log, use next consecutively numbered form.) I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm D.E. Derringer Co.

Signed Phil Derringer

Address 1136 Fountain St

Date 12-12-96

City, State, Zip Trotwood, Ohio 45426

ODH Registration Number 128

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy