

# WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources  
Division of Water, 1939 Fountain Square Drive  
Columbus, Ohio 43224 Phone (614) 265-6739

845024

Permit Number 193345

COUNTY Medina TOWNSHIP Wadsworth SECTION/LOT No. \_\_\_\_\_  
(Circle One)  
OWNER/BUILDER Don Hyshey PROPERTY ADDRESS 4554 Medina Line Rd  
(Circle One or Both) First Address of well location Number Street City  
LOCATION OF PROPERTY 1/2 mi. north of Johnson Rd W. side Zip Code +4 \_\_\_\_\_

## CONSTRUCTION DETAILS

**CASING** (Length below grade) Borehole Diameter 8-3/4 in. GROUT  
① Diameter 5 1/2 in. Length 81 ft. Wall Thickness .275 in. Material San Sals Volume used 300 #  
② Diameter \_\_\_\_\_ in. Length \_\_\_\_\_ ft. Wall Thickness \_\_\_\_\_ in. Method of installation  poured & driven   
Type: ☒ Steel ☐ Galv. ☐ PVC ☐ Other \_\_\_\_\_  
Depths: placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Joints: ☒ Threaded ☐ Welded ☐ Solvent ☐ Other \_\_\_\_\_  
GRAVEL PACK (Filter Pack)  
Material \_\_\_\_\_ Volume used \_\_\_\_\_  
Method of installation \_\_\_\_\_  
Liner: Length \_\_\_\_\_ Type \_\_\_\_\_ Wall Thickness \_\_\_\_\_ in. Depth: placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
**SCREEN**  
Type (wire wrapped, louvered, etc.) \_\_\_\_\_ Material \_\_\_\_\_  
Length \_\_\_\_\_ ft. Diameter \_\_\_\_\_ in. ☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other \_\_\_\_\_  
Set between \_\_\_\_\_ ft. and \_\_\_\_\_ ft. Slot \_\_\_\_\_ in. Date of Completion 11-13-96

## WELL LOG\*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:  
sandstone, shale, limestone, gravel, clay, sand, etc.

|                                 | From       | To         |
|---------------------------------|------------|------------|
| <u>yellow clay &amp; gravel</u> | <u>0</u>   | <u>10</u>  |
| <u>Brown sandstone</u>          | <u>10</u>  | <u>26</u>  |
| <u>soft grey shale</u>          | <u>26</u>  | <u>80</u>  |
| <u>grey shale</u>               | <u>80</u>  | <u>83</u>  |
| <u>grey sandstone</u>           | <u>83</u>  | <u>91</u>  |
| <u>grey shale</u>               | <u>91</u>  | <u>105</u> |
| <u>white sandstone</u>          | <u>105</u> | <u>150</u> |

## WELL TEST

☒ Bailing ☐ Pumping\* ☐ Other \_\_\_\_\_  
Test rate 15 gpm Duration of test 1 hrs.  
Drawdown 48 ft.  
Measured from: ☐ top of casing ☒ ground level ☐ Other \_\_\_\_\_  
Static Level (depth to water) 82 ft. Date: 11-13-96  
Quality (clear, cloudy, taste, odor) clean

\*(Attach a copy of the pumping test record, per section 1521.05, ORC)


## PUMP

Type of pump \_\_\_\_\_ Capacity \_\_\_\_\_ gpm  
Pump set at \_\_\_\_\_ ft.  
Pump installed by \_\_\_\_\_

## WELL LOCATION

Location of well in State Plane coordinates, if available:  
Zone \_\_\_\_\_ x \_\_\_\_\_ y \_\_\_\_\_  
Elevation of well \_\_\_\_\_ ft./m. Datum plain: ☐ NAD27 ☐ NAD83  
Source of coordinates: ☐ GPS ☐ Survey ☐ Other \_\_\_\_\_

Sketch a map showing distance well lies from numbered state highways,  
street intersections, county roads, buildings or other notable landmarks.



(If additional space is needed to complete well log, use next consecutively numbered form.) I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Fowler Drilling Inc Signed A.C. Fowler  
Address 3363 E. State St. Date 11-13-96  
City, State, Zip Barberton Ohio 44203 ODH Registration Number 195