

# WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources  
Division of Water, 1939 Fountain Square Drive  
Columbus, Ohio 43224 Phone (614) 265-6739

846879

Permit Number 103-96

COUNTY Warren TOWNSHIP Harlem SECTION/LOT No. \_\_\_\_\_  
(Circle One)

OWNER/BUILDER Wendell Abney PROPERTY ADDRESS 7384 Whitaker Rd Bathsville, O.  
(Circle One or Both) First Last (Address of well location) Number Street City  
Zip Code + 4 45152

LOCATION OF PROPERTY 7384 Whitaker Rd 4th Unit SK 132

## CONSTRUCTION DETAILS

**CASING** (Length below grade) Borehole Diameter \_\_\_\_\_ in.  
① Diameter 5-3/4 in. Length 59 ft. Wall Thickness 1/42 in. Material \_\_\_\_\_ Volume used \_\_\_\_\_  
② Diameter \_\_\_\_\_ in. Length \_\_\_\_\_ ft. Wall Thickness \_\_\_\_\_ in. Method of installation \_\_\_\_\_  
Type: ① Steel ② Galv. ③ PVC ④ Other \_\_\_\_\_  
Joints: ① Threaded ② Welded ③ Solvent ④ Other \_\_\_\_\_  
Liner: Length \_\_\_\_\_ Type \_\_\_\_\_ Wall Thickness \_\_\_\_\_ in. Depth: placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
**SCREEN**  
Type (wire wrapped, louvered, etc.) \_\_\_\_\_ Material \_\_\_\_\_  
Length \_\_\_\_\_ ft. Diameter \_\_\_\_\_ in.  
Set between \_\_\_\_\_ ft. and \_\_\_\_\_ ft. Slot \_\_\_\_\_  
**GROUT**  
Depth: placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Pitless Device ☒ Adapter ☐ Preassembled unit  
Use of Well Single Family  
☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other \_\_\_\_\_  
Date of Completion 12-12-96

## WELL LOG\*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:  
sandstone, shale, limestone, gravel, clay, sand, etc.

|                           | From | To  |
|---------------------------|------|-----|
| Brown clay hard           | 0    | 4   |
| light gray clay & sand    | 4    | 13  |
| yellow clay & gravel hard | 13   | 28  |
| green clay hard           | 28   | 31  |
| blue shale rock           | 31   | 59  |
| Water 59 ft               |      |     |
| Limestone                 |      |     |
| Limestone & shale hard    | 59   | 135 |
| hard & soft               |      |     |

## WELL TEST

☒ Bailing ☐ Pumping\* ☐ Other \_\_\_\_\_  
Test rate 2 gpm Duration of test 2 1/2 hrs.  
Drawdown 134 ft.  
Measured from: ☐ top of casing ☒ ground level ☐ Other \_\_\_\_\_  
Static Level (depth to water) 15 ft. Date: 12  
Quality (clear, cloudy, taste, odor) Clear

\*(Attach a copy of the pumping test record, per section 1521.05, ORC)


## PUMP

Type of pump Sub Capacity 10 gpm  
Pump set at 128 ft.  
Pump installed by Dick Naydip

## WELL LOCATION

Location of well in State Plane coordinates, if available:  
Zone \_\_\_\_\_ x \_\_\_\_\_ y \_\_\_\_\_  
Elevation of well \_\_\_\_\_ ft./m. Datum plain: ☐ NAD27 ☐ NAD83  
Source of coordinates: ☐ GPS ☐ Survey ☐ Other \_\_\_\_\_

Sketch a map showing distance well lies from numbered state highways,  
street intersections, county roads, buildings or other notable landmarks.



(If additional space is needed to complete well log, use next consecutively numbered form.) I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Dick Naydip & Son Signed Dick Naydip

Address 2213 SK 133 N Date 12-12-96

City State, Zip Blanchester, O, 45717 ODH Registration Number 1532