

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

849027

Permit Number

COUNTY Fayette
OWNER/BUILDER Philly L. Brown
(Circle One or Both) First Last

TOWNSHIP Green
PROPERTY ADDRESS 2793 Stanton Sugar Grove Rd.
(Address of well location) Number Street City

SECTION/LOT No.
(Circle One)

LOCATION OF PROPERTY Behind Church in Standley 2.7 miles on Right Zip Code 43102

CONSTRUCTION DETAILS

CASING (Length below grade)		Borehole Diameter <u>7</u> in.		GROUT	
1 Diameter <u>6</u> in.	Length <u>27</u> ft.	Wall Thickness <u>3/4</u> in.	Material	Volume used	
2 Diameter	Length	ft	Wall Thickness	in. Method of installation	
Type 1 Steel <u>✓</u> Galv. 2 PVC	1	2	1	Depth: placed from ft. to ft.	
2	2	2	2	GRAVEL PACK (Filter Pack)	
Joints: 1 Threaded <u>✓</u> Welded 2 Solvent	1	2	1	Material Volume used	
2	2	2	2	Method of installation	
Liner Length	Type	Wall Thickness	in.	Depth: placed from ft. to ft.	
SCREEN				Pitless Device <u>✓</u> Adapter Preassembled unit	
Type (wire wrapped, louvered, etc.)				Use of Well <u>Flow Meter</u>	
Length ft. Diameter				in. Rotary <u>✓</u> Cable Augered Driven Dig Other	
Set between ft. and ft. Slot				Date of Completion <u>7-3-97</u>	

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
<u>Topsoil</u>	<u>0</u>	<u>6</u>
<u>Dark sand</u>	<u>6</u>	<u>12</u>
<u>Sandy gravel</u>	<u>12</u>	<u>27</u>
<u>Steeple bitumens</u>	<u>27</u>	<u>39</u>
<u>Pit water</u>	<u>39</u>	<u>44</u>
<u>Well 44 FT Deep</u>		

WELL TEST

✓ Bailing Pumping Other
Test rate 8 gpm Duration of test 4 hrs.
Drawdown Over flow ft.
Measured from: 1 top of casing ground level Other
Static Level (depth to water) Over flow ft. Date: 8-27-97
Quality (clear, cloudy, taste, odor) Clear

*(Attach a copy of the pumping test record, per section 1521.05, ORC)


PUMP

Type of pump 5 hp submersible Capacity Restrictor 3 gpm
Pump set at 35 ft. Head 100 ft.
Pump installed by Y. J. Short & Co. Inc.

WELL LOCATION

Location of well in State Plane coordinates, if available:
Zone 18 x 1 y
Elevation of well 100 ft./m Datum plain: NAD27 NAD83
Source of coordinates: GPS Survey Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks



(If additional space is needed to complete well log, use next consecutively numbered form.) I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Y. J. Short & Co. Inc.
Address 2793 Stanton Sugar Grove Rd.
City, State, Zip Stanton, Ohio 43102

Signed Y. J. Short
Date 7-3-97
ODH Registration Number 22054