

DNR 7802.94
TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224 Phone (614) 265-6739

849609

Permit Number 195694

COUNTY Highland

TOWNSHIP Fairfield

SECTION/LOT No.
(Circle one)

OWNER/BUILDER Wayne Mullet
(Circle One or Both) First Last

PROPERTY ADDRESS 10378 Thomas Rd
(Address of well location) Number Street City Leesburg, OH

LOCATION OF PROPERTY Same

Zip Code 45135

CONSTRUCTION DETAILS

CASING (Length below grade)				Borehole Diameter	in.	GROUT						
1 Diameter	<u>6</u>	in.	Length*	<u>61</u>	ft.	Wall Thickness	in.	Material	Volume used			
2 Diameter		in.	Length*		ft.	Wall Thickness	in.	Method of installation				
Type:	1 Steel	2 Galv.	1 PVC	1		2 Other		Depth: placed from	ft. to			
Joints:	1 Threaded	2 Welded	1 Solvent	1		2 Other		GRAVEL PACK (Filter Pack)				
Liner:	Length	Type	Wall Thickness	in.		Depth: placed from	ft. to	Material	Volume used			
						Method of installation						
						Depth: placed from	ft. to					
						Pitless Device	Adapter	Preassembled unit				
						Use of Well	<u>residential</u>					
						in.	1 Rotary	2 Cable	Augered	Driven	Dug	Other
						Date of Completion	<u>May</u>					

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
<u>Clay</u>	<u>0</u>	<u>18</u>
<u>Sand & Gravel</u>	<u>18</u>	<u>21</u>
<u>Mud Sand</u>	<u>21</u>	<u>43</u>
<u>Hard pa</u>	<u>43</u>	<u>66</u>
<u>Limestone</u>	<u>66</u>	<u>90</u>

WELL TEST

Bailing	<u>15</u>	Pumping*	<u>3</u>	Other	
Test rate	<u>15</u>	gpm	Duration of test	<u>3</u>	hrs.
Drawdown	<u>30</u>				ft.
Measured from:	<u>top of casing</u>	<u>1</u>	ground level	<u>Other</u>	
Static Level (depth to water)	<u>18</u>	ft.	Date:	<u>May 1987</u>	
Quality (clear, cloudy, taste, odor)	<u>clear</u>				

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump	<u>submersible</u>	Capacity	<u>10</u>	gpm
Pump set at	<u>75</u>			ft.
Pump installed by	<u>owner H.C. Johnson Well Driller</u>			

WELL LOCATION

Location of well in State Plane coordinates, if available:
Zone x y
Elevation of well ft./m. Datum plain: NAD27 NAD83
Source of coordinates: GPS Survey Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks.

North

W
E
S
T

E
A
S
T

South

(If additional space is needed to complete well log, use next consecutively numbered form.) I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm H. C. Johnson Well Driller

Signed H. C. Johnson

Address 6806 Stafford Rd

Date May 1987

City, State, Zip Washington C. H. Ohio 43160

ODH Registration Number 01327

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE COLS, OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy