


TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

874273

WELL LOCATION	CONSTRUCTION DETAILS
County <u>LICKING</u> Township <u>MONROE</u>	☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Other _____
Owner/Builder <u>XXXXX</u> <u>CHRIS COOK</u> (Circle One or Both) First Last	BOREHOLE/CASING (measured from ground surface)
Address of Well Location <u>12700 BLAMER ROAD</u> Number Street Name	1 ☐ Borehole Diameter <u>7-7/8</u> inches Depth <u>113</u> ft. Casing Diameter <u>5</u> in. Length <u>107</u> ft. Thickness <u>SDR 21</u> in.
City <u>JOHNSTOWN</u> Zip Code <u>43031</u>	2 ☐ Borehole Diameter _____ inches Depth _____ ft. Casing Diameter _____ in. Length _____ ft. Thickness _____ in.
Permit No. <u>5089</u> Section/Plot No. _____ (Circle One or Both)	Casing Height Above Ground <u>1</u> ft.
Location of Well in State Plane coordinates, if available: ☐ N ☒ X ☐ S ☒ Y <u>0.000</u> +/- _____ ft. or m	Type 1 ☐ Steel 1 ☐ Galv. 1 ☒ PVC 1 ☐ _____ 2 ☐ _____ 2 ☐ _____ 2 ☐ _____ 2 ☐ Other _____
Elevation of Well _____ +/- _____ ft. or m	Joints 1 ☐ Threaded 1 ☐ Welded 1 ☒ Solvent 1 ☐ _____ 2 ☐ _____ 2 ☐ _____ 2 ☐ _____ 2 ☐ Other _____
Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source _____	SCREEN
Source of Coordinates: ☐ GPS ☐ Survey ☐ Other _____	Diameter <u>5</u> Slot Size <u>0.050"</u> Screen Length <u>6</u> ft.
Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____ North  South	Type <u>MACHINE SLOT</u> Material _____
	Set Between <u>110</u> ft. and <u>104</u> ft.
	GRAVEL PACK (Filter Pack)
	Material/Size No. <u>4 SAND</u> Volume/Weight Used <u>750 LBS.</u>
	Method of Installation <u>GRAVITY</u>
	Depth: Placed FROM <u>113</u> ft. TO <u>100</u> ft.
	GROUT
	Material <u>BENSEAL-AGC</u> Volume/Weight Used <u>245 GALS.</u>
	Method of Installation <u>TREMIE</u>
	Depth: Placed FROM <u>100</u> ft. TO SURFACE _____ ft.
WELL TEST*	DRILLING LOG*
Pre-Pumping Static Level <u>58</u> ft. Date <u>12/02/99</u>	INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.
Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other _____	Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.
☒ Air ☐ Bailing ☐ Pumping* ☐ Other _____	
Test Rate <u>30</u> gpm Duration of Test <u>1</u> hrs.	
Feet of Drawdown <u>12</u> ft. Sustainable Yield _____ gpm	
*(Attach a copy of the pumping test record, per section 1521.05, ORC)	
Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No	
Quality <u>CLEAR</u>	
PUMP/PITLESS	
Type of pump <u>SUBMERSIBLE</u> Capacity <u>10</u> gpm	
Pump set at <u>90</u> ft. Pitless Type <u>DICKENS</u>	
Pump installed by <u>SPROWLS DRILLING COMPANY</u>	
I hereby certify the information given is accurate and correct to the best of my knowledge.	
Drilling Firm <u>SPROWLS DRILLING COMPANY</u>	
Address <u>565 WEST CHERRY ST.; PO BOX 107</u>	
City, State, Zip <u>SUNBURY, OH 43074</u>	
Signed <u>Gary Sprohls</u> Date <u>12/16/99</u>	Note: Well is approximate, based on driller's general description and approximate depths.
ODH Registration Number <u>1731</u>	*(If more space is needed to complete drilling log, use next consecutively numbered form.)
	Date of Well Completion <u>12/03/99</u> Total Depth of Well <u>113</u> ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy