

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

874274

WELL LOCATION		CONSTRUCTION DETAILS	
County	UNION	☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Other	
Township	JEROME	BOREHOLE/CASING (measured from ground surface)	
Owner/Builder (Circle One or Both)	AUTUMNWOOD HOMES	1 Borehole Diameter	7-7/8 inches Depth 47 ft.
First		Casing Diameter	5 in. Length 49 ft. Thickness SDR 21 in.
Last		2 Borehole Diameter	4-3/4 inches Depth 79 ft.
Address of Well Location	9191 KETCH ROAD	Casing Diameter	in. Length ft. Thickness in.
Number		Casing Height Above Ground	1 ft.
City	PLAIN CITY	Type	1 Steel 1 Galv. 1 ☒ PVC 1 Other
Permit No.	2304-99	2	2 2 2 2
Location of Well in State Plane coordinates, if available:	Use of Well RESIDENTIAL	2	2 2 2 2
N X o 0.000 +/- ft. or m		Joints	1 Threaded 1 Welded 1 ☒ Solvent 1 Other
S Y +/- ft. or m		2	2 2 2 2
Elevation of Well		SCREEN	
Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source		Diameter	Slot Size Screen Length ft.
Source of Coordinates: ☐ GPS Survey ☐ Other		Type	Material
Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: Long:		Set Between	ft. and
		GRAVEL PACK (Filter Pack)	
		Material/Size	Volume/Weight Used
		Method of Installation	
		Depth: Placed FROM	ft. TO
		GROUT	
		Material	BENSEAL-AGC Volume/Weight Used 140 GAL.
		Method of Installation	1" TREMIE
		Depth: Placed FROM 47	ft. TO SURFACE
		DRILLING LOG*	
		INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.	
		Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.	
			From To
		BROWN CLAY	0 10
		GRAY CLAY	10 38
		LIMESTONE	38 126
		WATER @ 115'	
WELL TEST*			
Pre-Pumping Static Level	29 ft.	Date	09/01/99
Measured from: ☒ Top of Casing ☐ Ground Level Other			
☒ Air ☐ Bailing ☐ Pumping* ☐ Other			
Test Rate	30 gpm	Duration of Test	0.75 hrs.
Feet of Drawdown	20 ft.	Sustainable Yield	gpm
*(Attach a copy of the pumping test record, per section 1521.05, ORC)			
Is Copy Attached?	Yes ☒ No	Flowing Well?	☐ Yes ☒ No
Quality	CLEAR		
PUMP/PITLESS			
Type of pump	SUBMERSIBLE	Capacity	10 gpm
Pump set at	60 ft.	Pitless Type	DICKENS
Pump installed by SPROWLS DRILLING COMPANY			
I hereby certify the information given is accurate and correct to the best of my knowledge.			
Drilling Firm	SPROWLS DRILLING COMPANY		
Address	565 WEST CHERRY ST.; PO BOX 107		
City, State, Zip	SUNBURY, OH 43074		
Signed	Ealy Sproles Jr		
ODH Registration Number	1731	Date	12/17/99
		Note: Well is approximate, based on driller's general description and approximate depths.	
		*(If more space is needed to complete drilling log, use next consecutively numbered form.)	
		Date of Well Completion	12/09/99
		Total Depth of Well	126 ft.