DNR 7602.96

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Divison of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

874400

WELL LOCATION

County HOCKING Township GREEN

Owner/Builder (Circle One or Both) JOYCE FOISTER (First / Last)

Address of Well Location 36044 GREASEY RIDGE Rd (Number / Street Name)

City LOGAN Zip Code +4 43138

Permit No. 128-99 Section/Lot No. (Circle One or Both)

Location of Well in State Plane coordinates, if available: Use of Well HOUSE WELL

N ☐ X _____ . _____ +/- _____ ft. or m

S ☐ Y _____ . _____ +/- _____ ft. or m

Elevation of Well _____ . _____ +/- _____ ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source _____

Source of Coordinates: ☐ GPS ☐ Survey ☐ Other _____

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____



WELL TEST*

Pre-Pumping Static Level 226 ft. Date 10-12-99

Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other _____

☒ Air ☐ Bailing ☐ Pumping* ☐ Other _____

Test Rate 10-12 gpm Duration of Test 2HRS hrs.

Feet of Drawdown 286 ft. Sustainable Yield _____ gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☐ No Flowing Well? ☐ Yes ☐ No

Quality _____

PUMP/PITLESS

Type of pump F-W Capacity 1HP gpm

Pump set at 350 ft. Pitless Type LS10

Pump installed by T.L. UNDERHILL

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm _____

Address T. L. UNDERHILL

City, State, Zip 1789 ITAWAMBA TRAIL LONDON, OHIO 43140

Signed [signature] Date 10-12-99

ODH Registration Number 0794

CONSTRUCTION DETAILS

☑ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Other _____

BOREHOLE/CASING (measured from ground surface)

1☐ Borehole Diameter 8 3/4 inches Depth 140 ft.

Casing Diameter 5" in. Length 140 ft. Thickness SDR17 in.

2☐ Borehole Diameter _____ inches Depth _____ ft.

Casing Diameter _____ in. Length _____ ft. Thickness _____ in.

Casing Height Above Ground _____ ft.

Type: 1☐ 2☐ Steel; 1☐ 2☐ Galv.; 1☒ 2☐ PVC; 1☐ 2☐ Other _____

Joints: 1☐ 2☐ Threaded; 1☐ 2☐ Welded; 1☒ 2☐ Solvent; 1☐ 2☐ Other _____

SCREEN

Diameter _____ Slot Size _____ Screen Length _____ ft.

Type _____ Material _____

Set Between _____ ft. and _____ ft.

GRAVEL PACK (Filter Pack)

Material/Size _____ Volume/Weight Used _____

Method of Installation _____

Depth: Placed FROM _____ ft. TO _____ ft.

GROUT

Material Benseal Volume/Weight Used 240 lbs

Method of Installation T-P.

Depth: Placed FROM 140 ft. TO Surface ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED. Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.	From	To
YELLOW Clay SandStone	0	18
Yellow-SandStone-BlueShale	18	140
Blue Shale-SandStone	140	445
Yellow SandStone.	445	454
well at	445	

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 10-12-99 Total Depth of Well 454 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971