


WELL LOG AND DRILLING REPORT

878219

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARDOhio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503**WELL LOCATION**County Richland Township SharonOwner/Builder Gerald KreinbrinkAddress of Well Location 4539 Stein Rd.City Crestline Zip Code +4 44827Permit No. 00-54N Section of No. 31Location of Well in State Plane Coordinates, if available: Use of Well: ResidentialN ☒ X ft. or mS ☐ Y ft. or mElevation of Well ft. or mDatum Plain: ☐ NAD27 ☐ NAD83 Elevation Source Source of Coordinates: ☐ GPS ☐ Survey ☐ Other Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: Long:
North**WELL TEST***Pre-Pumping Static Level 28 ft. Date 5/2/00Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other ☐ Air ☒ Bailing ☐ Pumping* ☐ Other Test Rate 10 gpm Duration of Test 1.5 hrs.Feet of Drawdown 7 ft. Sustainable Yield 10 gpm

(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ NoQuality Sulfur detected.**PUMP/PITLESS**Type of pump Capacity gpmPump set at ft. Pitless Type Pump installed by

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Woodworth Drilling & Pump Svc.Address 1820 St Rt 598City, State, Zip Galion OH 44833Signed Paul Woodworth Date 5/4/00ODH Registration Number 01456**CONSTRUCTION DETAILS**☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other **BOREHOLE/CASING** (measured from ground surface)1 ☒ Borehole Diameter 5 1/2 inches Depth 52 ft.Casing Diameter 5 in. Length 50 1/2 ft. Thickness .244 in.2 ☐ Borehole Diameter inches Depth ft.Casing Diameter in. Length ft. Thickness in.Casing Height Above Ground 1 ft.Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ Other 2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other Joints 1 ☒ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐ Other 2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other **SCREEN**Diameter Slot Size Screen Length ft.Type Material Set Between ft. and ft.**GRAVEL PACK** (Filter Pack)Material/Size Volume/Weight Used Method of Installation Depth: Placed FROM ft. TO ft.**GROUT**Material Bentonite Volume/Weight Used 57#Method of Installation PouredDepth: Placed FROM Surface ft. TO ft.**DRILLING LOG***

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Clay & Gravel	0	12
Clay	12	23
Clay & Gravel	23	41
Gray Shale & Sandstone	41	52
TD	52	

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 5/2/00 Total Depth of Well 52 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy