

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

878364

WELL LOCATION

County Trumbull Township Hartford

Owner/Builder Dave Gibbs
(Circle One or Both) First Last

Address of Well Location 5822 Everett Hall
Number Street Name

City _____ Zip Code +4 _____

Permit No. 274678 Section/Lot No. _____
(Circle One or Both)

Location of Well in State Plane coordinates, if available: Use of Well DOMESTIC

N ☒ X _____ +/- _____ ft. or m


S ☐ Y _____ +/- _____ ft. or m

Elevation of Well _____ +/- _____ ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source _____

Source of Coordinates: ☐ GPS ☐ Survey ☐ Other _____

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____

**WELL TEST***

Pre-Pumping Static Level 21 ft. Date 5-12-99

Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other _____

☐ Air ☒ Bailing ☐ Pumping* ☐ Other _____

Test Rate 12 gpm Duration of Test ONE hrs.

Feet of Drawdown 5 ft. Sustainable Yield 12 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No

Quality clear

PUMP/PITLESS

Type of pump submersible Capacity 8 gpm

Pump set at 58 ft. Pitless Type merrell

Pump installed by WE BORN 6-7-99

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm BORN DRILLING

Address PO Box 252

City, State, Zip Bristolville, OH 44402

Signed WE BORN Date 5-13-99

ODH Registration Number 578

CONSTRUCTION DETAILS

☐ Rotary ☒ Cable ☐ Augered ☒ Driven ☐ Other _____

BOREHOLE/CASING (measured from ground surface)

1 Borehole Diameter _____ inches Depth _____ ft.

Casing Diameter 6.98 in. Length 44 ft. Thickness 1.88 in.

2 Borehole Diameter _____ inches Depth _____ ft.

Casing Diameter _____ in. Length _____ ft. Thickness _____ in.

Casing Height Above Ground _____ ft.

Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ Other _____

2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other _____

Joints 1 ☐ Threaded 1 ☒ Welded 1 ☐ Solvent 1 ☐ Other _____

2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other _____

SCREEN

Diameter _____ Slot Size _____ Screen Length _____ ft.

Type _____ Material _____

Set Between _____ ft. and _____ ft.

GRAVEL PACK (Filter Pack)

Material/Size _____ Volume/Weight Used _____

Method of Installation _____

Depth: Placed FROM _____ ft. TO _____ ft.

GROUT

Material Blue clay Volume/Weight Used 50 LB

Method of Installation GROUT

Depth: Placed FROM 42 ft. TO TOP ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

From To

Brown clay	0	5
Blue clay	5	24
Blue clay - sand	24	31
Soft shale	31	41
shale	41	62
Gravel - sand	62	63
shale	63	64

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy