

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

878724

County

MONROE

Township

SUMMIT

Owner/Builder

JEFF REUSSER

Address of Well Location

49486 SR 145

City

LEWISVILLE

Zip Code +4

3754

Permit No.

17

Section/Lot No.

14

Location of Well in State Plane coordinates, if available:

N

X

ft. or m

S

Y

ft. or m

Elevation of Well

ft. or m

Datum Plain:

NAD27

NAD83

Elevation Source

Source of Coordinates:

GPS

Survey

Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: Long: North

☐ Rotary

☒ Cable

☐ Augered

☐ Driven

☐ Other

BOREHOLE/CASING

(measured from ground surface)

1

Borehole Diameter

13

inches

Depth

29

ft.

2

Casing Diameter

8

in.

Length

31

ft.

Thickness

1/2

in.

2

Borehole Diameter

inches

Depth

ft.

2

Casing Diameter

in.

Length

ft.

Thickness

in.

2

Casing Height Above Ground

18

ft.

Type

1

Steel

1

Galv.

1

PVC

1

Other

2

Steel

2

Galv.

2

PVC

2

Other

1

Threaded

1

Welded

1

Solvent

1

Other

2

Threaded

2

Welded

2

Solvent

2

Other

SCREEN

Diameter

8

ft.

Slot Size

3/8

Hole

Screen Length

13

ft.

Type

Material

PVC

Set Between

16

ft. and

29

ft.

GRAVEL PACK (Filter Pack)

Material/Size

#8 PEA GRAVEL

Volume/Weight Used

1000 lb.

Method of Installation

POURED

Depth: Placed FROM

16

ft. TO

29

ft.

GROUT

Material

CEMENT GROUT

Volume/Weight Used

1040 lb.

Method of Installation

POURED

Depth: Placed FROM

3

ft. TO

16

ft.

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
light brown sandy clay (soft)	0	6
yellow clay (soft)	6	13
light brown sandstone (very hard)	13	16
blue sandstone (very hard)	16	17
gray shale (soft)	17	29

water at 20 ft.

Pre-Pumping Static Level

8

ft.

Date

9/7/00

Measured from:

☐ Top of Casing

☒ Ground Level

☐ Other

☐ Air

☒ Bailing

☐ Pumping

☐ Other

Test Rate

12

gpm

Duration of Test

1

hrs.

Feet of Drawdown

21

ft.

Sustainable Yield

12

gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached?

☐ Yes

☒ No

Flowing Well?

☐ Yes

☒ No

Quality

cloudy

no taste

PUMP/PITLESS

Type of pump

by owner

Capacity

gpm

Pump set at

ft.

Pitless Type

Pump installed by

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm

WILHELM'S DRILLING SERVICE

Address

43872 TH 256

City, State, Zip

LEWISVILLE OHIO 43754

Signed

John Wilhelm

Date

9/7/00

ODH Registration Number

1562