

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

880107

WELL LOCATION

County CLAWFORD Township LIBERTY

Owner/Builder JERRY LILLY

Address of Well Location 3310 A. D. GERTON ANNAPOLIS

City ANNAPOLIS Zip Code 21403

Permit No. 52 Section/Lot No. 6

Location of Well in State Plane coordinates, if available:

Elevation of Well 10 ft. or m

Datum Plain: NAD27 Elevation Source Survey

Source of Coordinates: ☒ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: 38° 45' 40" N Long: 76° 42' 10" W

W

East

South

North

CONSTRUCTION DETAILS

Rotary ☐ Cable ☐ Augered ☒ Driven ☐ Other ☐

BOREHOLE/CASING (measured from ground surface)

1. Borehole Diameter 27 inches Depth 23 ft

Casing Diameter 5 in. Length 21 ft. Thickness 1/4 in

2. Borehole Diameter 27 inches Depth 23 ft

Casing Diameter 5 in. Length 21 ft. Thickness 1/4 in

Casing Height Above Ground 1 ft

Type 2 Steel 2 Galv. 1 PVC 1 Other 2

Joints 1 Threaded 1 Welded 1 Solvent 1 Other 2

SCREEN

Diameter 5 Slot Size 040 Screen Length 2 ft

Type SLOTTED Material PVC

Set Between 21 ft. and 23 ft

GRAVEL PACK (Filter Pack)

Material/Size 1/2" - 3/4" Volume/Weight Used 2 TON

Method of Installation POURED

Depth: Placed FROM 18 ft. TO 23 ft

GROUT

Material CEMENT Volume/Weight Used 12 BAGS

Method of Installation POURED

Depth: Placed FROM 4 ft. TO 18 ft

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

BROWN CLAY

GRAY CLAY

SAND & WATER

From

To

0

10

10

18

18

23

NO WATER BELOW

WELL TEST*

Pre-Pumping Static Level 1 ft. Date 10/10/10

Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other

☐ Air ☐ Bailing ☒ Pumping* ☐ Other

Test Rate 15 gpm Duration of Test 1 hrs

Feet of Drawdown 1 ft. Sustainable Yield 15 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☒ Yes ☐ No

Quality Good

PUMP/PITLESS

Type of pump Hand Pump Capacity 10 gpm

Pump set at 1 ft. Pitless Type None

Pump installed by Hand

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm LILLY'S WELL DRILLING

Address 1083 SR 100

City, State, Zip Buckles MD 21040

Signed James Lilly Date 10/10/10

ODH Registration Number 717