

WELL LOCATION

CONSTRUCTION DETAILS

County Wood Township Montgomery

Owner/Builder Tin Man Heating
(Circle One or Both) First Last

Address of Well Location 6559 Holcolmb Rd.
Number Street Name

City Wayne Zip Code +4 43466

Permit No. 316 412 Section/Lot No. (Circle One or Both)

Location of Well in State Plane coordinates, if available: Use of Well Residential

N ☐ X +/- ft. or m
S ☐ Y +/- ft. or m

Elevation of Well +/- ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source

Source of Coordinates: ☐ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: Long:
North

Holcolmb Rd
kwell Rhoades
West
South

☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☒ Borehole Diameter 9 inches Depth 25 ft.

Casing Diameter 6 in. Length 26 ft. Thickness SPR 21 in.

2 ☐ Borehole Diameter inches Depth ft.

Casing Diameter in. Length ft. Thickness in.

Casing Height Above Ground ft.

Type 1 ☐ Steel 1 ☐ Galv. 1 ☒ PVC 1 ☐ Other

2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other

Joints 1 ☐ Threaded 1 ☐ Welded 1 ☒ Solvent 1 ☐ Other

2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other

SCREEN

Diameter Slot Size Screen Length ft.

Type Material

Set Between ft. and ft.

GRAVEL PACK (Filter Pack)

Material/Size Volume/Weight Used

Method of Installation

Depth: Placed FROM ft. TO ft.

GROUT

Material Bensuel Volume/Weight Used 300#

Method of Installation Machine

Depth: Placed FROM 0 ft. TO 25 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

From To

Soil 0 2

Clay 2 12

Limestone 12 180

WELL TEST*

Pre-Pumping Static Level 20 ft. Date 12-1-00

Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other

☒ Air ☐ Bailing ☐ Pumping* ☐ Other

Test Rate 12 gpm Duration of Test 1 1/2 hrs.

Feet of Drawdown 40 ft. Sustainable Yield 12 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No

Quality Good - Light Sulfur

PUMP/PITLESS

Type of pump Capacity gpm

Pump set at ft. Pitless Type

Pump installed by

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Clearwater of Ohio

Address Wayne, Ohio

City, State, Zip Wayne, Ohio

Signed Charles H. Hines Date 12-1-00

ODH Registration Number 2488

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 12-1-00 Total Depth of Well 180 ft.