


WELL LOG AND DRILLING REPORTTYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARDOhio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

887168

WELL LOCATION**CONSTRUCTION DETAILS**County Monroe Township SwitzerlandOwner/Builder Ray Shaver
(Circle One or Both) First LastAddress of Well Location 49745 Switzerland Twp. Rd. 198
Number Street NameCity Clarington Zip Code +4 43915Permit No. 14 Section/Lot No.
(Circle One or Both)Location of Well in State Plane
coordinates, if available:N ☐ X +/- ft. or mS ☐ Y +/- ft. or mElevation of Well +/- ft. or mDatum Plain: ☐ NAD27 ☐ NAD83 Elevation Source Source of Coordinates: ☐ GPS ☐ Survey ☐ Other Sketch a map showing distance well lies from numbered state highways, street
intersections, county roads, buildings or other notable landmarks. If latitude and
longitude are available please include here: Lat: Long:
North**WELL TEST***Pre-Pumping Static Level ft. Date Measured from: ☐ Top of Casing ☐ Ground Level ☐ Other ☐ Air ☐ Bailing ☐ Pumping* ☐ Other Test Rate gpm Duration of Test hrs.Feet of Drawdown ft. Sustainable Yield gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☐ No Flowing Well? ☐ Yes ☐ NoQuality **PUMP/PITLESS**Type of pump Capacity gpmPump set at ft. Pitless Type Pump installed by

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Duncan Bros. Drilling, Inc.Address Box 136City, State, Zip New Galilee, Pa. 16141Signed Cindy Duncan Date 5/8/02ODH Registration Number 1556☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Other **BOREHOLE/CASING** (measured from ground surface)1 ☒ Borehole Diameter 13 3/4" inches Depth 38' ft.Casing Diameter 10" in. Length 40' ft. Thickness in.2 ☒ Borehole Diameter 9 7/8" inches Depth 40-250' ft.Casing Diameter in. Length ft. Thickness in.Casing Height Above Ground ft.Type 1 ☐ Steel 1 ☐ Galv. 1 ☒ PVC 1 ☐2 ☐ 2 ☐ 2 ☐ 2 ☐ Other Joints 1 ☐ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐2 ☐ 2 ☐ 2 ☐ 2 ☐ Other **SCREEN**Diameter Slot Size Screen Length ft.Type Material Set Between ft. and ft.**GRAVEL PACK** (Filter Pack)Material/Size Volume/Weight Used Method of Installation Depth: Placed FROM ft. TO ft.**GROUT**Material Volume/Weight Used Method of Installation Depth: Placed FROM ft. TO ft.**DRILLING LOG***

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Top soil	0.0	0.5
Red shale	.5	1.5
Brown shale	1.5	15.0
Red shale	15.0	21.0
Gray shale	21.0	35.5
Red shale	35.5	40.5
Gray sandstone	40.5	53.0
Gray shale	53.0	57.5
Gray sandstone	57.5	60.0
Gray shale	60.0	70.0
Limestone	70.0	72.5
Limy gray shale	72.5	82.0
Limestone	82.0	87.5
Limy gray shale	87.5	92.0
Red shale	92.0	107.5
Gray sandstone	107.5	112.0
Sandy gray shale	112.0	118.5
Gray sandstone	118.5	122.0
Red shale	122.0	129.0
Gray sandstone	129.0	149.5
Sandy gray shale	149.5	155.0
Gray sandstone	155.0	157.0
Sandy gray shale	157.0	169.0
Gray sandstone	169.0	171.5
Gray shale	171.5	184.5
Gray sandstone	184.5	191.0

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion con't pg. 2 Total Depth of Well ft.Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

887169

[illegible]

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNr, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy