

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

890045

WELL LOCATION

County Belmont Township Wayne

Owner/Builder Dianna Seal
(Circle One or Both) First Last

Address of Well Location 54405 Newcastle RD
Number Street Name

City Beaumont Zip Code +4 43716

Permit No. 01 Section/Lot No. (Circle One or Both)

Location of Well in State Plane coordinates, if available: Use of Well House

N X ft. or m


S Y ft. or m

Elevation of Well ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source

Source of Coordinates: ☐ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: North Long:



CONSTRUCTION DETAILS

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1) Borehole Diameter 10" inches Depth 1-25 ft.

Casing Diameter 5" in. Length 102 ft. Thickness SPR 21 in.

2) Borehole Diameter 8" inches Depth 25-100 ft.

Casing Diameter 5" in. Length 102 ft. Thickness SPR 21 in.

Casing Height Above Ground 18" ft.

Type 1 Steel 1 Galv. 1 PVC 1 Other

2 2 2 2

Joints 1 Threaded 1 Welded 1 Solvent 1 Other

2 2 2 2

SCREEN

Diameter 5 Slot Size 5/16 Screen Length 30 ft.

Type PVC Material

Set Between 40-50 ft. and 80-100 ft.

GRAVEL PACK (Filter Pack)

Material/Size #8 Rec Volume/Weight Used 2 Ton

Method of Installation Gravity

Depth: Placed FROM 25 ft. TO 100 ft.

GROUT

Material Hole Plus Volume/Weight Used 600 LB

Method of Installation Gravity

Depth: Placed FROM 1 ft. TO 25 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Brown Sand Stone	1	38
Blue Sand Stone	38	47
Gray Shale	47	82
Line Stone	82	100

WELL TEST*

Pre-Pumping Static Level 35 ft. Date 2-13-02

Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other

Air ☐ Bailing ☐ Pumping* ☒ Other Pump

Test Rate 95 gpm Duration of Test 3 hrs.

Feet of Drawdown 95 ft. Sustainable Yield 12 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☒ Yes ☐ No Flowing Well? ☒ Yes ☐ No

Quality Good

water AT

42 FT

PUMP/PITLESS

Type of pump Goulds 1/2 HP Capacity 10 gpm

Pump set at 95 ft. Pitless Type Dickens

Pump installed by CTR WWD

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm CTR Water Well Drilling

Address RT 2 Box 106B

City, State, Zip Coveil Ohio 45744

Signed Vernon D. Tetter Date 2-13-02

ODH Registration Number 00262

If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 2-13-02 Total Depth of Well 100 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy