

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

894400

WELL LOCATION

County **Meigs** Township **Salisbury**

Owner/Builder **Village of Pomeroy**
(Circle One or Both) First Last

Address of Well Location **Well Field 320 E. Main St**
Number Street Name

City **Pomeroy** Zip Code +4 **45769**

Permit No. Section/Lot No.
(Circle One or Both)

Location of Well in State Plane
coordinates, if available:


N ☒ X ☐ S ☐ Y ☐ Use of Well ☐ +/- ft. or m

Elevation of Well ☐ +/- ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source

Source of Coordinates: ☐ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: Long:

**WELL TEST***

Pre-Pumping Static Level **35** ft. Date **9/7/00**

Measured from: Top of Casing ☒ Ground Level ☐ Other

Air ☐ Bailing ☐ Pumping* ☒ Other

Test Rate **7532** gpm Duration of Test **24** hrs.

Feet of Drawdown **6.9** ft. Sustainable Yield gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No

Quality

PUMP/PITLESS

Type of pump **None** Capacity gpm

Pump set at ft. Pitless Type **Bker**

Pump installed by

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm **Moody's of Dayton DBA GM Baker &**

Address **335 Hosack St** Son

City, State, Zip **Columbus, OH 43207**

Signed **Stanley J. Bunk**

Date **8/22/01**

ODH Registration Number **636**

CONSTRUCTION DETAILS

☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1. Borehole Diameter **30** inches Depth **95** ft.

Casing Diameter **-** in. Length ft. Thickness in.

2. Borehole Diameter inches Depth ft.

Casing Diameter **16** in. Length **75'** ft. Thickness **3/8** in.

Casing Height Above Ground ft.

Type 1 ☐ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ Other

2 ☒ Joints 1 ☐ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐ Other

SCREEN

Diameter **16"** Slot Size **0.060** Screen Length **20** ft.

Type **Wire Wrapped** Material **Stainless Steel**

Set Between **75** ft. and **95** ft.

GRAVEL PACK (Filter Pack)

Material/Size **#4** Volume/Weight Used **12 Tons**

Method of Installation **Pour**

Depth: Placed FROM **30** ft. TO **95'** ft.

GROUT

Material **Cement/bentonite** Volume/Weight Used **7 yds**

Method of Installation **pour**

Depth: Placed FROM **5** ft. TO **30** ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

From To

Brown Silt Clay 0 30'

Fine to MED sand cobbles med grv 30 40'

Fine to coarse sand- gravel 40 45'

Fine to med sand- gravel 45 50'

Fine to coarse sand gravel 50 55'

Fine to coarse sand gravel cobbles 55 70'

Fine to coarse sand*gravel 70 80'

Fine to coarse sand*grav boulders 80 85'

Fine to coarse sand*gravel cobb 85 90'

Fine to coarse sand, gravel, clay and Limestone 90 95'

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion Total Depth of Well **95** ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNr, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy