

WELL LOG AND DRILLING REPORTTYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARDOhio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

900786

WELL LOCATION		CONSTRUCTION DETAILS	
County SENECA	Township CLINTON	☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Other BOREHOLE/CASING (measured from ground surface)	
Owner/Builder Brian Woodall (Circle One or Both) First Last		1 ☒ Borehole Diameter 7 7/8" inches	Depth 32 ft.
Address of Well Location 434 E Co Rd 38 Number Street Name		Casing Diameter 5" in. Length 32 ft. Thickness	in.
City TIFFIN	Zip Code +4 44883	2 ☐ Borehole Diameter _____ inches	Depth _____ ft.
Permit No. 1034	Section/Plot No. #5 (Circle One or Both)	Casing Diameter _____ in. Length _____ ft. Thickness _____ in.	ft.
Location of Well in State Plane coordinates, if available:		Casing Height Above Ground _____ ft.	
N ☒ X	Use of Well _____	Type 1 ☐ Steel 1 ☐ Galv 1 ☒ PVC 1 ☐ Other	
S ☐ Y		2 ☐ Threaded 2 ☐ Welded 2 ☒ Solvent 2 ☐ Other	
Elevation of Well _____ ft. or m		SCREEN	
Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source _____		Diameter _____ Slot Size _____ Screen Length _____ ft.	
Source of Coordinates. GPS _____ Survey _____ Other _____		Type _____ Material _____	
Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____ North _____		Set Between _____ ft. and _____ ft.	
		GRAVEL PACK (Filter Pack)	
		Material/Size _____ Volume/Weight Used _____	
		Method of Installation _____	
		Depth: Placed FROM _____ ft. TO _____ ft.	
		GROUT	
		Material BENTONITE Volume/Weight Used 50 #	
		Method of Installation TREMIE	
DRILLING LOG* INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED. Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.		Depth: Placed FROM 0 ft. TO 30 1/2 ft.	
		From _____ To _____	
		Top soil	0 3
		Sandy CLAY	3 27
		Lime Stone	27 121
WELL TEST Pre-Pumping Static Level 82 ft Date 5-24-01 Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other Air _____ Bailing ☒ Pumping _____ Other _____ Test Rate 20 gpm Duration of Test 2 hrs. Feet of Drawdown _____ ft. Sustainable Yield _____ gpm (Attach a copy of the pumping test record per section 1521.05, ORC) Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No Quality clear			
PUMP/PITLESS Type of pump _____ Capacity _____ gpm Pump set at _____ ft Pitless Type _____ Pump installed by OWNER I hereby certify the information given is accurate and correct to the best of my knowledge. Drilling Firm J & J Builders of TIFFIN, INC Address 750 E Twp Rd 1172 City State Zip TIFFIN Ohio 44883 Signed [Signature] Date 5-31-01 ODH Registration Number 392			
(If more space is needed to complete drilling log, use next consecutively numbered form.) Date of Well Completion 5-24-01 Total Depth of Well 121 ft.			