

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

905115

WELL LOCATION		CONSTRUCTION DETAILS																
County Portage	Township Atwater	☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other																
Owner/Builder (Circle One or Both) JAMES CASH	First Last	BOREHOLE/CASING (measured from ground surface)																
Address of Well Location 7117 Virginia Rd	Number Street Name	1 ☒ Borehole Diameter 6 1/2 inches	Depth 118 ft.															
City Atwater	Zip Code +4 44201	Casing Diameter 7" in. Length 111 ft.	Thickness 272 in.															
Permit No 00-21	Section/Lot No. (Circle One or Both)	2 ☐ Borehole Diameter _____ inches	Depth _____ ft.															
Location of Well in State Plane coordinates, if available:	Use of Well SINGLE-FAMILY	Casing Diameter _____ in. Length _____ ft.	Thickness _____ in.															
N ☒ X	ft or m	Casing Height Above Ground 30"	ft.															
S ☐ Y	ft or m	Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐																
Elevation of Well _____ ft or m		2 ☐	2 ☐ Other _____															
Datum Plain: ☐ NAD27 ☐ NAD83	Elevation Source	Joints 1 ☒ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐																
Source of Coordinates: ☐ GPS ☐ Survey ☐ Other		2 ☐	2 ☐ Other _____															
Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____		SCREEN																
		Diameter 4" Slot Size .032 Screen Length 8' ft.																
		Type machine slotted-teles Material PVC																
		Set Between 110 coping ft. and 118 ft.																
		GRAVEL PACK (Filter Pack)																
Material/Size _____ Volume/Weight Used _____		Material Benseal Volume/Weight Used 100 lbs																
Method of Installation _____		Method of Installation Dry Driven																
Depth: Placed FROM _____ ft. TO _____ ft.		Depth: Placed FROM 0 ft. TO 110 ft.																
GROUT		DRILLING LOG*																
INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.		Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.																
		<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>From</th> <th>To</th> </tr> </thead> <tbody> <tr> <td>Brown Clay</td> <td>0</td> <td>20</td> </tr> <tr> <td>gray clay + sand mix</td> <td>20</td> <td>108</td> </tr> <tr> <td>gray clay</td> <td>108</td> <td>109</td> </tr> <tr> <td>(WATER) Sand + gravel</td> <td>109</td> <td>118</td> </tr> </tbody> </table>			From	To	Brown Clay	0	20	gray clay + sand mix	20	108	gray clay	108	109	(WATER) Sand + gravel	109	118
	From	To																
Brown Clay	0	20																
gray clay + sand mix	20	108																
gray clay	108	109																
(WATER) Sand + gravel	109	118																
Pre-Pumping Static Level 37 ft. Date 4-7-01 Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other ☐ Air ☒ Bailing ☒ Pumping ☐ Other Test Rate 7 gpm Duration of Test 6 hrs. Feet of Drawdown 30 ft. Sustainable Yield 6 gpm *(Attach a copy of the pumping test record, per section 1521.05, ORC) Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No Quality Good																		
PUMP/PITLESS																		
Type of pump Submersible Capacity 5 gpm																		
Pump set at 85 ft. Pileless Type pitless adapter																		
Pump installed by _____																		
I hereby certify the information given is accurate and correct to the best of my knowledge.																		
Drilling Firm A+H Drilling																		
Address 14945 Horning Ave																		
City, State, Zip Alliance Ohio 44601																		
Signed Jim Hanner Date 4-7-01																		
ODH Registration Number 1394																		
*(If more space is needed to complete drilling log, use next consecutively numbered form.) Date of Well Completion 4-7-01 Total Depth of Well 120 ft.																		