

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Columbus, Ohio

No 90692

County Franklin Township Springfield Section of Township Sec 25
Owner Mike Smotrshla Address Petersburg
Location of property R 90

CONSTRUCTION DETAILS

Casing diameter 3 3/8 Length of casing 44
Type of screen 1/2 inch Length of screen 10
Type of pump Submersible
Capacity of pump 10 G.P.M.
Depth of pump setting 10

PUMPING TEST

Pumping rate 10 G.P.M. Duration of test 1 hrs.
Drawdown 10 ft. Date July 11, 1982
Developed capacity 10 G.P.M.
Static level 10 ft. Depth to water 10 ft.
Pump installed by R 90

WELL LOG

Formations
Sandstone, shale, limestone
gravel and clay

From To

0 Feet Ft.

Clay
Clay + Gravel
Limestone

15

44

44

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N.

INSTRUCTIONS

The Well Log and Drilling Report forms are designed to be filled out by the driller. A copy of each log shall be furnished to the Division of Water. Such log shall be kept on file by the Division of Water. We suggest that you be as accurate as possible in recording this data as it may be used in the future for planning and developing of new water supplies. An accurate location of the well is equally as important as an accurate well log. In the space allotted for a map, sketch the position of the well in relation to numbered state highways, railroad crossings, street intersections, etc. If the property is located on a county or township road show its position in relation to the nearest state highways.

DEPARTMENT OF NATURAL RESOURCES

Division of Water
Columbus, Ohio

S.

See reverse side for instructions

Drilling Firm Ross Latta
Address East Palestine

Date July 11, 1982
Signed Ross Latta

2315
LOCATED