

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

914457

WELL LOCATION

County Licking Township Si Albano

Owner/Builder FRANKLIN D. EDWARDS
(Circle One or Both) First Last

Address of Well Location 5377 WHITEHEAD RD. SE.
Number Street Name

City Branford Zip Code 43023

Permit No. 7176 Section/Lot No. (Circle One or Both)

Location of Well in State Plane coordinates, if available:

N ☐ X ☒ +/- ft. or m


S ☐ Y ☒ +/- ft. or m

Elevation of Well +/- ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source

Source of Coordinates: ☐ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____
North



WELL TEST*

Pre-Pumping Static Level 20 ft. Date 10-15-03

Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other

☐ Air ☒ Bailing ☒ Pumping* ☐ Other

Test Rate 10 gpm Duration of Test 6 hrs.

Feet of Drawdown 15 ft. Sustainable Yield 3000 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☒ Yes ☐ No Flowing Well? ☐ Yes ☐ No

Quality

PUMP/PITLESS

Type of pump Submersible Capacity 10 gpm

Pump set at 85 ft. Pitless Type Yes Pickens

Pump installed by Asherast Drilling

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Asherast Drilling

Address 10578 Hazle Dell Rd

City, State, Zip Newark Oh. 43055

Signed Frank D. Edwards

Date 10-23-03

ODH Registration Number 1188

CONSTRUCTION DETAILS

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☒ Borehole Diameter 5 1/2 inches Depth 88 ft.

Casing Diameter 5 1/2 in. Length 88 ft. Thickness 1.25 in.

2 ☐ Borehole Diameter _____ inches Depth _____ ft.

Casing Diameter _____ in. Length _____ ft. Thickness _____ in.

Casing Height Above Ground 18 in _____ ft.

Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐

2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other

Joints 1 ☒ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐

2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other

SCREEN

Diameter N/A Slot Size _____ Screen Length _____ ft.

Type _____ Material _____

Set Between _____ ft. and _____ ft.

GRAVEL PACK (Filter Pack)

Material/Size _____ Volume/Weight Used _____

Method of Installation N/A

Depth: Placed FROM _____ ft. TO _____ ft.

GROUT

Material _____ Volume/Weight Used _____

Method of Installation N/A

Depth: Placed FROM _____ ft. TO _____ ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
<u>Soft Sand</u>	<u>0</u>	<u>15</u>
<u>Soft Shale</u>	<u>15</u>	<u>35</u>
<u>Soft Shale</u>	<u>35</u>	<u>80</u>
<u>Coarse Gravel + Sand</u>	<u>80</u>	<u>88</u>
<u>I.D.</u>		<u>88 ft.</u>

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy

[illegible]