

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

914663

WELL LOCATION

County Ashtabula Township Andover

Owner/Builder Brenda + Tony Gibson

Address of Well Location 6790 Maple Ave

City Andover Zip Code +4 44003

Permit No. 13 Section/Lot No. 0

Location of Well in State Plane coordinates, if available:

N ☐ X 41 35 +/- 317 ft. or m

S ☐ Y 80 32 +/- 411 ft. or m

Elevation of Well +/- ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source

Source of Coordinates: ☒ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: Long:

West

5. Lake

Pine

well

W Maple Ave

South

East

CONSTRUCTION DETAILS

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☐ Borehole Diameter 6 inches Depth 99 ft.

Casing Diameter 6 7/8 in. Length 30 ft. Thickness 188 in.

2 ☐ Borehole Diameter inches Depth ft.

Casing Diameter in. Length ft. Thickness in.

Casing Height Above Ground 24" ft.

Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐

2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other

Joints 1 ☐ Threaded 1 ☒ Welded 1 ☐ Solvent 1 ☐

2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other

SCREEN

Diameter Slot Size Screen Length ft.

Type Material

Set Between ft. and ft.

GRAVEL PACK (Filter Pack)

Material/Size Volume/Weight Used

Method of Installation

Depth: Placed FROM ft. TO ft.

GROUT

Material Bentonite Volume/Weight Used 30

Method of Installation Dry Driven

Depth: Placed FROM 0 ft. TO 50 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

Brown Clay

Gray Shale

From

To

0

20

20

99.

WELL TEST*

Pre-Pumping Static Level 15 ft. Date 8-9-07

Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other

☐ Air ☒ Bailing ☐ Pumping* ☐ Other

Test Rate 14 gpm Duration of Test 1 hrs.

Feet of Drawdown ft. Sustainable Yield 14 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☐ No Flowing Well? ☐ Yes ☐ No

Quality

PUMP/PITLESS

Type of pump Submersible Capacity 10 gpm

Pump set at 7.5 ft. Pitless Type Pull Through

Pump installed by Charles Himes

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Himes Well Drilling

Address 2027 Crom Rd

City, State, Zip Essexville Pa 16424

Signed Charles Himes Date 8-9-07

ODH Registration Number 860

(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 8-9-07 Total Depth of Well 99 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy