

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

916728

WELL LOCATION

County SENECA Township ADAMS

Owner/Builder CHARLES MASON

Address of Well Location 8300 E. TWP. RD. 138

City REPUBLIC Zip Code +4 44867
Permit No. 99087 Section/Plot No. 34

Location of Well in State Plane coordinates, if available: Use of Well RESIDENTIAL

N ☒ X +/- ft. or m


S ☐ Y +/- ft. or m

Elevation of Well +/- ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source

Source of Coordinates: ☐ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: Long:
North



South
WELL TEST*

Pre-Pumping Static Level 16 ft. Date 6/23/00

Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other

☐ Air ☒ Bailing ☐ Pumping* ☐ Other

Test Rate 20 gpm Duration of Test 1 hrs.

Feet of Drawdown ft. Sustainable Yield 20 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No

Quality no sulfur

PUMP/PITLESS

Type of pump Capacity gpm

Pump set at ft. Pitless Type

Pump installed by

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm WOODWORTH DRILLING & PUMP SERVICE

Address 1820 ST. RT. 598

City, State, Zip GALION, OHIO 44833

Signed Scott Woodworth Date 7/2/00

ODH Registration Number 1456

CONSTRUCTION DETAILS

☒ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☐ Borehole Diameter 5 1/2 inches Depth 80 ft.

Casing Diameter 5 in. Length 36 ft. Thickness .244 in.

2 ☐ Borehole Diameter inches Depth ft.

Casing Diameter in. Length ft. Thickness in.

Casing Height Above Ground 1 ft.

Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ Other

2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other

Joints 1 ☒ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐ Other

2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other

SCREEN

Diameter Slot Size Screen Length ft.

Type Material

Set Between ft. and ft.

GRAVEL PACK (Filter Pack)

Material/Size Volume/Weight Used

Method of Installation

Depth: Placed FROM ft. TO ft.

GROUT

Material GRANULAR BENTONITE Volume/Weight Used 47#

Method of Installation POURED

Depth: Placed FROM SURFACE ft. TO ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
CLAY & GRAVEL	0	19
BROKEN LIME	19	36
LIMESTONE	36	80
TD.	80	

West East

South

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 6/23/00 Total Depth of Well 80 ft.