

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

917321

WELL LOCATION

County Licking Township Liberty

Owner/Builder Tom Larason

Address of Well Location 5978 Castle Road

City Alexandria Zip Code +4 43001

Permit No. 7991

Location of Well in State Plane coordinates, if available:

Use of Well Domestic

Elevation of Well 918 ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source GPS

Source of Coordinates: ☒ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: Long:

West

East

North

South

Concord Road
Castle Rd.

CONSTRUCTION DETAILS

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☒ Borehole Diameter 8 inches Depth 33 ft.

Casing Diameter 5 1/2 in. Length 33 ft. Thickness 1/4 in.

2 ☒ Borehole Diameter 5 inches Depth 28 ft.

Casing Diameter none in. Length ft. Thickness in.

Casing Height Above Ground 1 foot ft.

Type

1 ☐ Steel

2 ☐ Galv.

1 ☒ PVC

2 ☐ Other Rock

Joints

1 ☐ Threaded

2 ☐ Welded

1 ☒ Solvent

2 ☐ Other

SCREEN NA

Diameter Slot Size Screen Length

Type Material

Set Between ft. and ft.

GRAVEL PACK (Filter Pack)

Material/Size Volume/Weight Used

Method of Installation

Depth: Placed FROM ft. TO ft.

GROUT

Material Bentonite Volume/Weight Used 3 bags

Method of Installation pour in

Depth: Placed FROM 0 ft. TO 33 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

From

To

yellow clay
gray rock
gray shale and sandstone

0
20
24

20
24
61

water at 55 feet

WELL TEST*

Pre-Pumping Static Level 24 ft. Date 12-2-05

Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other

☐ Air ☒ Bailing ☐ Pumping* ☐ Other

Test Rate 10 gpm Duration of Test hrs.

Feet of Drawdown 0 ft. Sustainable Yield 10 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No

Quality clear

PUMP/PITLESS

Type of pump submersible Capacity 10 gpm

Pump set at 50 ft. Pitless Type Merrill

Pump installed by W. Garrabrant

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Garrabrant Well Drilling

Address 7749 Concord Rd.

City, State, Zip Johnstown, Oh 43031

Signed Walter J. Garrabrant Date 12-28-05

ODH Registration Number 932

(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 12-5-05 Total Depth of Well 61 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971
 Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy