

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

921163**WELL LOCATION****CONSTRUCTION DETAILS**

County Preble Township Monroe

☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Other _____

BOREHOLE/CASING (measured from ground surface)

Owner/Builder Kevin Smallwood - contractor

1 ☒ Borehole Diameter 7 7/8 inches Depth 65 ft.

Owner/Builder Terry Mann - owner

Casing Diameter 5 in. Length 50 ft. Thickness SDR21 in.

Address of Well Location 8395 St. Rt. 127

2 ☐ Borehole Diameter _____ inches Depth _____ ft.

Casing Diameter _____ in. Length _____ ft. Thickness _____ in.

City West Manchester Zip Code +4 45382

Casing Height Above Ground _____ ft.

Permit No. 2342 Section/Lot No. _____

Type 1 ☐ Steel 1 ☐ Galv. 1 ☒ PVC 1 ☐

Location of Well in State Plane coordinates, if available: Use of Well existing home

2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other _____

N ☐ X _____ ft. or m

Joints 1 ☐ Threaded 1 ☐ Welded 1 ☒ Solvent 1 ☐

S ☐ Y _____ ft. or m

2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other _____

Elevation of Well _____ ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source _____

Source of Coordinates: ☐ GPS ☐ Survey ☐ Other _____

SCREEN

Diameter 5 Slot Size .020 Screen Length 3 ft.

Type wrapped Material PVC

Set Between 50 ft. and 53 ft.

GRAVEL PACK (Filter Pack)

Material/Size Quartz Gravel Volume/Weight Used 45 gal.

Method of Installation gravity

Depth: Placed FROM 48 ft. TO 60 ft.

GROUT

Material Benseal & E-2 Mud Volume/Weight Used 75 gal.

Method of Installation pumped

Depth: Placed FROM 0 ft. TO 48 ft.

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____

North

Foss Road

Banta Rd.

well X

127 St. Rt.

South

WELL TEST*

Pre-Pumping Static Level 18 ft. Date 9-25-00

Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other _____

☒ Air ☐ Bailing ☐ Pumping* ☐ Other _____

Test Rate 50 gpm Duration of Test 1 hrs.

Feet of Drawdown 10 ft. Sustainable Yield _____ gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No

Quality clear

PUMP/PITLESS

Type of pump _____ Capacity _____ gpm

Pump set at _____ ft. Pitless Type _____

Pump installed by _____

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Wiley Well Drilling, Inc.

Address 7774 E. ST. RD. 32

City, State, Zip Union City, Indiana 47390

Signed Jack Wigner Date 9/25/00

ODH Registration Number 164

DRILLING LOG* TT-4

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

From To

Brown Clay 0 15'

Brown Clay & Gravel 15' 25'

Tan Gravel & Sand 25' 33'

Clay 33' 40'

Small Gravel 40' 53'

Gray Clay 53' 65'

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 9-25-00 Total Depth of Well 53 ft.