

WELL LOG AND DRILLING REPORT

ORIGINAL

$X = 251 \ 3,100$
 $Y = N \ 500 \ 200 \pm 500$

State of Ohio
 DEPARTMENT OF NATURAL RESOURCES
 Division of Water
 Columbus, Ohio

No 92972

County Madison Township Boardman Section of Township Mr. Henry Deer
 or Lot Number
 Owner Mr. Fielder Burkholder Address 1921 Ridge Lawn Ave
 Location of property H 804 Boardman & Garfield Rd

CONSTRUCTION DETAILS

Casing diameter 6 Length of casing 114-6
 Type of screen — Length of screen —
 Type of pump —
 Capacity of pump —
 Depth of pump setting —

PUMPING TEST


Pumping rate 10 G.P.M. Duration of test 7 hrs.
 Drawdown Bottom ft. Date 7/20-53
 Developed capacity 10 gpm
 Static level—depth to water 60 ft
 Pump installed by Over

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>Yellow clay</u>	0 Feet	12 Ft.
<u>Blue clay & shale</u>	12	60
<u>Sand</u>	60	112
<u>Slab Rock</u>	112	117
<u>Blue Limestone</u>	117	119
<u>Blue & Rock</u>	119	164
<u>Gravel</u>		

SKETCH SHOWING LOCATION

Locate in reference to numbered
 State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm Arthur Evans Date 7-1954
 Address 24 E Delaware Ave Signed Arthur Evans

(39)