

WELL LOG AND DRILLING REPORTTYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARDOhio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

932553

WELL LOCATION		CONSTRUCTION DETAILS		
County <u>Licking</u>	Township <u>Harrison</u>	Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other ☐		
Owner/Builder (Circle One or Both) <u>Tom Wilson</u>	Address of Well Location <u>3444 Stoney Hill</u>	BOREHOLE/CASING (measured from ground surface)		
City <u>Newark</u>	Zip Code +4 <u>3055</u>	1. Borehole Diameter <u>9</u> inches	Depth <u>220</u> ft.	
Permit No. <u>622</u>	Section/Lot No. (Circle One or Both)	Casing Diameter <u>5</u> in.	Length <u>220</u> ft. Thickness <u>.450</u> in.	
Location of Well in State Plane coordinates, if available:	Use of Well <u>Home</u>	2. Borehole Diameter <u>5</u> inches	Depth <u>280</u> ft.	
N ☒ S ☐ E ☐ W ☐		Casing Diameter _____ in.	Length _____ ft. Thickness _____ in.	
Elevation of Well _____ ft. or in.		Casing Height Above Ground <u>12+</u>		
Datum Plain: ☐ NAD27 ☐ NAD83	Elevation Source _____	Type 1 Steel ☐ 2 Galv. ☒ 3 PVC ☐ 4 Other ☐		
Source of Coordinates: ☐ GPS ☐ Survey ☐ Other		Joints 1 Threaded ☐ 2 Welded ☒ 3 Solvent ☐ 4 Other ☐		
Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____ North _____ South _____		SCREEN		
		Diameter _____	Slot Size _____	Screen Length _____ ft.
		Type _____	Material _____	
		Set Between _____	ft. and _____	ft.
Material/Size _____ Volume/Weight Used _____ Method of Installation _____ Depth: Placed FROM _____ ft. TO _____ ft.		GRAVEL PACK (Filter Pack)		
Material <u>Benseal</u> Volume/Weight Used <u>300 lb</u> Method of Installation <u>Free Fall</u> Depth: Placed FROM <u>0</u> ft. TO <u>220</u> ft.		GROUT		
DRILLING LOG* INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED. Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc. From To <u>Brown SHALE 0 75</u> <u>Yellow Sandstone 75 92</u> <u>Brown Sandstone 92 205</u> <u>Gray Sandstone 205 260</u> <u>Light Sand 260 280</u>				
WELL TEST*				
Pre-Pumping Static Level <u>30</u> ft.	Date <u>2-23-02</u>			
Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other				
Air ☐ Bailing ☒ Pumping ☐ Other				
Test Rate <u>10+</u> gpm	Duration of Test <u>2</u> hrs.			
Feet of Drawdown <u>0</u> ft.	Sustainable Yield <u>10+</u> gpm			
*(Attach a copy of the pumping test record, per section 1521.05, ORC)				
Is Copy Attached? ☐ Yes ☐ No	Flowing Well? ☐ Yes ☐ No			
Quality _____				
PUMP/PITLESS				
Type of pump <u>Sub.</u>	Capacity <u>10+</u> gpm			
Pump set at <u>140</u> ft.	Pitless Type <u>Orkens</u>			
Pump installed by <u>Harry Bevard JR.</u>				
I hereby certify the information given is accurate and correct to the best of my knowledge.				
Drilling Firm <u>HSA Waterwell Drilling</u>				
Address <u>3066 Martinsburg</u>				
City, State, Zip <u>Newark, OH 43082</u>				
Signed <u>Harry A Bevard Jr.</u>	Date <u>2-23-02</u>			
ODH Registration Number <u>1039</u>				
		*(If more space is needed to complete drilling log, use next consecutively numbered form.)		
		Date of Well Completion <u>2-23-02</u> Total Depth of Well <u>280</u> ft.		

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNr, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy