

WELL LOG AND DRILLING REPORTTYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARDOhio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

933125

WELL LOCATION	CONSTRUCTION DETAILS
County <u>Ashland</u> Township <u>Troy</u>	☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other _____
Owner/Builder <u>Darrell Williams</u> (Circle One or Both) First Last	BOREHOLE/CASING (measured from ground surface)
Address of Well Location <u>28570 Torch Rd.</u> Number Street Name	1 ☐ Borehole Diameter <u>10</u> inches Depth <u>110</u> ft. Casing Diameter <u>6</u> in. Length <u>110</u> ft. Thickness <u>SDR 21</u> in.
City <u>Coolville OH</u> Zip Code +4 <u>45723</u>	2 ☐ Borehole Diameter _____ inches Depth _____ ft. Casing Diameter _____ in. Length _____ ft. Thickness _____ in.
Permit No. <u>2005001</u> Section/Lot No. _____ (Circle One or Both)	Casing Height Above Ground <u>1 1/2</u> ft.
Location of Well in State Plane coordinates, if available: Use of Well <u>LAWN - GARDEN</u>	Type 1 ☐ Steel 1 ☐ Galv. 1 ☒ PVC 1 ☐ _____ 2 ☐ _____ 2 ☐ _____ 2 ☐ _____ 2 ☐ Other _____
N ☐ X _____ +/- _____ ft. or m S ☐ Y _____ +/- _____ ft. or m	Joints 1 ☐ Threaded 1 ☐ Welded 1 ☒ Solvent 1 ☐ _____ 2 ☐ _____ 2 ☐ _____ 2 ☐ _____ 2 ☐ Other _____
Elevation of Well _____ +/- _____ ft. or m	SCREEN
Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source _____	Diameter <u>Private Pipe</u> Slot Size <u>1/16</u> Screen Length <u>20</u> ft.
Source of Coordinates: ☐ GPS ☐ Survey ☐ Other _____	Type <u>PVC well liner</u> Material _____
Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____ North _____	Set Between <u>75</u> ft. and <u>95</u> ft.
	GRAVEL PACK (Filter Pack)
	Material/Size <u>20# gravel</u> Volume/Weight Used <u>2000 lbs</u>
	Method of Installation <u>Hand washed in</u>
	Depth: Placed FROM <u>110</u> ft. TO <u>30</u> ft.
	GROUT
	Material <u>Benecel small grain</u> Volume/Weight Used <u>300 lbs</u>
	Method of Installation <u>Dry Poured in slow</u>
	Depth: Placed FROM <u>30</u> ft. TO <u>95.3</u> ft.
WELL TEST*	DRILLING LOG*
Pre-Pumping Static Level <u>40</u> ft. Date <u>5-15-05</u>	INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.
Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other _____	Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.
☐ Air ☒ Bailing ☐ Pumping* ☐ Other _____	
Test Rate <u>3</u> gpm Duration of Test <u>1</u> hrs.	
Feet of Drawdown <u>35</u> ft. Sustainable Yield <u>3</u> gpm	
*(Attach a copy of the pumping test record, per section 1521.05, ORC)	
Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No	
Quality <u>Clear</u>	
PUMP/PITLESS	
Type of pump <u>Subm. Rod Jack</u> Capacity <u>12</u> gpm	
Pump set at <u>106</u> ft. Piless Type <u>Manned Braes</u>	
Pump installed by <u>Darrell Williams</u>	
I hereby certify the information given is accurate and correct to the best of my knowledge.	
Drilling Firm <u>Darrell Williams Drilling</u>	
Address <u>28570 Torch Rd.</u>	
City, State, Zip <u>Coolville OH 45723</u>	
Signed <u>Darrell Williams</u> Date <u>5-20-05</u>	(If more space is needed to complete drilling log, use next consecutively numbered form.)
ODH Registration Number <u>1131</u>	Date of Well Completion <u>5-15-05</u> Total Depth of Well <u>110</u> ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
 ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971
 Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy