

WELL LOG AND DRILLING REPORT

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARDOhio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

936531

WELL LOCATION

County Jackson Township Mill

Owner/Builder Dwayne Jackson
(Circle One or Both) First Last

Address of Well Location State Rt. 800
Number Street Name

City Uhrichville 908 Dearville Ave Zip Code +4 44683

Permit No. 367602 Section/Lot No.
(Circle One or Both)

Location of Well in State Plane coordinates, if available: Use of Well

N ☐ X +/- ft. or m


S ☐ Y +/- ft. or m

Elevation of Well +/- ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source

Source of Coordinates: ☐ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: Long:



CONSTRUCTION DETAILS

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☒ Borehole Diameter 6 1/2 inches Depth 1414/02 ft

Casing Diameter 6 1/2 in. Length 504 ft. Thickness .317 in.

2 ☐ Borehole Diameter inches Depth ft.

Casing Diameter in. Length ft. Thickness in.

Casing Height Above Ground 4 1/2 ft

Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ Other

2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other

Joints 1 ☒ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐ Other

2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other

SCREEN

Diameter Slot Size Screen Length ft.

Type Material

Set Between ft. and ft.

GRAVEL PACK (Filter Pack)

Material/Size Volume/Weight Used

Method of Installation

Depth: Placed FROM ft. TO ft.

GROUT

Material Clay Benseal Volume/Weight Used

Method of Installation

Depth: Placed FROM 46 ft. TO 3 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Shale	0	11
sandstone	11	29
Shale	29	33
Coal	33	34
Clay	34	46
sandstone	46	96

Water at 63 ft

WELL TEST*

Pre-Pumping Static Level 63 ft. Date 11/20/02

Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other

☐ Air ☒ Bailing ☐ Pumping* ☐ Other

Test Rate 20 gpm Duration of Test 1/2 hrs.

Feet of Drawdown ft. Sustainable Yield 20 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☐ No Flowing Well? ☐ Yes ☒ No

Quality

PUMP/PITLESS

Type of pump Capacity gpm

Pump set at ft. Pitless Type

Pump installed by

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Unger Well Drilling

Address 91029 Greager Rd

City, State, Zip Dennison Ohio 44621

Signed Colin Unger Date 11/22/02

ODH Registration Number 01310

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 11/20/02 Total Depth of Well 96 ft