

WELL LOG AND DRILLING REPORT

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

939741

WELL LOCATION

County Portage Township Suffield

Owner/Builder Jeffery Barry
(Circle One or Both) First Last

Address of Well Location 1289 Portage Line Rd
Number Street Name

City Mogadore Zip Code +4 4240

Permit No. 03-171 Section/Lot No.
(Circle One or Both)

Location of Well in State Plane coordinates, if available: Use of Well Private

N ☐ X +/- ft. or m


S ☐ Y +/- ft. or m

Elevation of Well +/- ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source

Source of Coordinates: ☐ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: Long:



CONSTRUCTION DETAILS

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☐ Borehole Diameter 5 inches Depth 45 ft.

Casing Diameter 5 in. Length 34 1/2 ft. Thickness 1/4 in.

2 ☐ Borehole Diameter inches Depth ft.

Casing Diameter in. Length ft. Thickness in.

Casing Height Above Ground 18 ft.

Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐

2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other

Joints 1 ☒ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐

2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other

SCREEN

Diameter Slot Size Screen Length ft.

Type Material

Set Between ft. and ft.

GRAVEL PACK (Filter Pack)

Material/Size Volume/Weight Used

Method of Installation

Depth: Placed FROM ft. TO ft.

GROUT

Material no grout Volume/Weight Used 50

Method of Installation drudgemen

Depth: Placed FROM 0 ft. TO 45 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Clay	0	28
Limestone	28	35
shale	35	45

WELL TEST*

Pre-Pumping Static Level 6 ft. Date Oct 16/03

Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other

☐ Air ☒ Bailing ☐ Pumping* ☐ Other

Test Rate 15 gpm Duration of Test 1 1/2 hrs.

Feet of Drawdown 15 ft. Sustainable Yield 15 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☐ No Flowing Well? ☐ Yes ☒ No

Quality Good

PUMP/PITLESS

Type of pump Submersible Capacity 10 gpm

Pump set at 55 ft. Pitless Type Pull Through

Pump installed by Carl Lemon

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Carl Lemon

Address 1067 E. 1st St

City, State, Zip Mogadore OH 44240

Signed Carl Lemon Date Oct 14/03

ODH Registration Number 893

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion Oct 14/03 Total Depth of Well 45 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy