

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

944649

WELL LOCATION

County morrow Township Troy

Owner/Builder Tracy Kinn
(Last One or Both) First Last

Address of Well Location 9215 Ross Rd.
Number Street Name

City Lexington Zip Code +4 4904

Permit No. 20030052 Section/Lot No. 16
(Section One or Both)

Location of Well in State Plane coordinates, if available: Use of Well Residential

N ☒ X +/- ft. or m

S ☐ Y +/- ft. or m

Elevation of Well +/- ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source

Source of Coordinates: ☐ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: Long:

WELL TEST*

Pre-Pumping Static Level 76 ft. Date

Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other

☒ Air ☐ Bailing ☐ Pumping* ☐ Other

Test Rate 12 gpm Duration of Test 1 hrs.

Feet of Drawdown ft. Sustainable Yield 12 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☐ No Flowing Well? ☐ Yes ☐ No

Quality Clear

PUMP/PITLESS

Type of pump Capacity gpm

Pump set at ft. Pitless Type

Pump installed by Contractor

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Parker Well Drilling, Inc

Address 8855 Ross Rd.

City, State, Zip Lexington, OH 44904

Signed Fred Paschich Date 8-20-03

ODH Registration Number 2046

CONSTRUCTION DETAILS

☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☒ Borehole Diameter 7 7/8 inches Depth 94 ft.

Casing Diameter 5 in. Length 96 ft. Thickness .021 in.

2 ☐ Borehole Diameter inches Depth ft.

Casing Diameter in. Length ft. Thickness in.

Casing Height Above Ground 2 ft.

Type 1 ☐ Steel 1 ☐ Galv. 1 ☒ PVC 1 ☐

2 ☐ 2 ☐ 2 ☐ 2 ☐

Joints 1 ☐ Threaded 1 ☐ Welded 1 ☒ Solvent 1 ☐

2 ☐ 2 ☐ 2 ☐ 2 ☐

SCREEN

Diameter Slot Size Screen Length ft.

Type Material

Set Between ft. and ft.

GRAVEL PACK (Filter Pack)

Material/Size Volume/Weight Used

Method of Installation

Depth: Placed FROM ft. TO ft.

GROUT

Material EZ mud / Ben Seal Volume/Weight Used 150

Method of Installation Pumped Tremie

Depth: Placed FROM 94 ft. TO 0 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Brown Clay & Gravel	0	12
Gray Clay & Gravel	12	24
Brown Broken Sandstone	24	56
Brown Sandstone	56	94
Gray Sandstone	94	160

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 8-11-03 Total Depth of Well 160 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNr, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy