


WELL LOG AND DRILLING REPORT

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARDOhio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

947664

WELL LOCATION

CONSTRUCTION DETAILS

County Hocking Township LaurelOwner/Builder mark Lecky
(Check One or Both) First LastAddress of Well Location 26050 Big Pine Road
Number Street NameCity Logan, Ohio Zip Code +4 43206Permit No. 200734 Section/Lot No. 35
(Check One or Both)Location of Well in State Plane
coordinates, if available:Use of Well DomesticN ☐ X ☐ +/- 840 ft. or mS ☐ Y ☐ +/- 840 ft. or mElevation of Well 840 ft. or mDatum Plain: ☐ NAD27 ☐ NAD83 Elevation Source GPSSource of Coordinates: ☒ GPS ☐ Survey ☐ OtherSketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat 39°27.068' Long 82°32.830'
North☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☐ Borehole Diameter 5 inches Depth 25 ft.Casing Diameter 5 1/2 in. Length 25 ft. Thickness 5/16 in.2 ☐ Borehole Diameter inches Depth ft.Casing Diameter in. Length ft. Thickness in.Casing Height Above Ground 16" ft.Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ Other2 ☐ 2 ☐ 2 ☐ 2 ☐Joints 1 ☒ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐ Other2 ☐ 2 ☐ 2 ☐ 2 ☐

SCREEN

Diameter Slot Size Screen Length ft.Type Material Set Between ft. and ft.

GRAVEL PACK (Filter Pack)

Material/Size Volume/Weight Used Method of Installation Depth: Placed FROM ft. TO ft.

GROUT

Material BEN SEAL Volume/Weight Used 100 lbsMethod of Installation Dry-DrivenDepth: Placed FROM 25' ft. TO Surface ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

From

To

Fill0 3Brown Sandy Clay3 18Brown Sandrock18 23Gray Sandy Shale23 38Brown Sandrock38 44Gray Sandy shale44 55White Sandrock55 72Gray Shale72 80Water at
55 to 72

PUMP/PITLESS

Type of pump Sub Capacity 12 gpmPump set at 70 ft. Pitless Type Pull-thruPump installed by Poling Drilling

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Poling DrillingAddress 165 MARKS AVECity, State, Zip LANCASTER, OHIO 43130Signed Robert Poling Date July 13, 07ODH Registration Number 000414

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion July 13, 07 Total Depth of Well 80 ft.Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy