


**WELL LOG AND DRILLING REPORT**TYPE OR USE PEN  
SELF TRANSCRIBING  
PRESS HARDOhio Department of Natural Resources  
Division of Water, 1939 Fountain Square Drive  
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

947665

**WELL LOCATION**County Hocking Township Good hopeOwner/Builder Robert Martin  
(Circle One or Both) First LastAddress of Well Location 26673 MAIN ST.  
Number Street NameCity Rockbridge, Ohio Zip Code +4 43149Permit No. 06-99 Section/Lot No. 23  
(Circle One or Both)Location of Well in State Plane coordinates, if available: Use of Well DOMESTICN ☐ X ☐ +/- ft. or mS ☐ Y ☐ +/- ft. or mElevation of Well 762 +/- ft. or mDatum Plain: ☐ NAD27 ☐ NAD83 Elevation Source GPSSource of Coordinates: ☒ GPS ☐ Survey ☐ OtherSketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat 39°34.979 Long 82°31.448  
North**WELL TEST\***Pre-Pumping Static Level 0 ft. DateMeasured from: ☒ Top of Casing ☒ Ground Level ☐ Other☐ Air ☒ Bailing ☐ Pumping\* ☐ OtherTest Rate 20 gpm Duration of Test 2 hrs.Feet of Drawdown 70 ft. Sustainable Yield 20 gpm

\*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☐ No Flowing Well? ☐ Yes ☒ NoQuality clear to cloudy**PUMP/PITLESS**Type of pump Sub Capacity 12 gpmPump set at 90 ft. Pitless Type Pull-thruPump installed by Poling

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Poling DrillingAddress 165 Marks Ave.City, State, Zip LANCASTER, OhioSigned Robert PolingDate June 28, 07ODH Registration Number 000414**CONSTRUCTION DETAILS**☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other**BOREHOLE/CASING** (measured from ground surface)1 ☐ Borehole Diameter 5 inches Depth 99 ft.Casing Diameter 5 1/2 in. Length 99 ft. Thickness 5/16 in.2 ☐ Borehole Diameter \_\_\_\_\_ inches Depth \_\_\_\_\_ ft.

Casing Diameter \_\_\_\_\_ in. Length \_\_\_\_\_ ft. Thickness \_\_\_\_\_ in.

Casing Height Above Ground 2 ft.Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐2 ☐ 2 ☐ 2 ☐ 2 ☐ OtherJoints 1 ☒ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐2 ☐ 2 ☐ 2 ☐ 2 ☐ Other**SCREEN**

Diameter \_\_\_\_\_ Slot Size \_\_\_\_\_ Screen Length \_\_\_\_\_ ft.

Type \_\_\_\_\_ Material \_\_\_\_\_

Set Between \_\_\_\_\_ ft. and \_\_\_\_\_ ft.

**GRAVEL PACK** (Filter Pack)

Material/Size \_\_\_\_\_ Volume/Weight Used \_\_\_\_\_

Method of Installation \_\_\_\_\_

Depth: Placed FROM \_\_\_\_\_ ft. TO \_\_\_\_\_ ft.

**GROUT**Material Benseal Volume/Weight Used 225 lbsMethod of Installation Dry-DrivenDepth: Placed FROM 99 ft. TO Surface ft.**DRILLING LOG\***

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:  
sandstone, shale, limestone, gravel, clay, sand, etc.

|                          | From      | To         |
|--------------------------|-----------|------------|
| <u>Brown Clay</u>        | <u>0</u>  | <u>10</u>  |
| <u>Gray clay (sandy)</u> | <u>10</u> | <u>95</u>  |
| <u>Gray Sandy shale</u>  | <u>95</u> | <u>159</u> |

Water @ variousDepths from 110 to150 thru sandrock  
shells

\*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion June 21, 07 Total Depth of Well 159 ft.Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.  
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971  
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy