

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

955518

WELL LOCATION

County Delaware Township Tray

Owner/Builder Edward & Beth Mack

Address of Well Location 2260 Tray Road

City Delaware Zip Code +4 43015

Permit No. 1545-03

Location of Well in State Plane coordinates, if available:

Use of Well

Datum Plain: NAD27 NAD83 Elevation Source

Source of Coordinates: GPS Survey Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: Long:

North

West

Tray Road

meter Rd

Delaware

Tray #23

East

CONSTRUCTION DETAILS

Rotary Cable Augered Driven Other

Borehole/Casing (measured from ground surface)

Borehole Diameter 7.75 inches Depth 41 ft.

Casing Diameter 5 in. Length ft. Thickness in.

Borehole Diameter 5 inches Depth 29 ft.

Casing Diameter in. Length ft. Thickness in.

Casing Height Above Ground

Type Steel Galv. PVC Other

Joints Threaded Welded Solvent Other

SCREEN

Diameter Slot Size Screen Length ft.

Type Material

Set Between ft. and ft.

GRAVEL PACK (Filter Pack)

Material/Size Volume/Weight Used

Method of Installation

Depth: Placed FROM ft. TO ft.

GROUT

Material Ben Seal Volume/Weight Used 200 LB

Method of Installation Pumped

Depth: Placed FROM 40 ft. TO Surface ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

From To

Sand & gravel

0 30

Limestone

30 70

WELL TEST*

Pre-Pumping Static Level 30 ft. Date 12/30

Measured from: Top of Casing Ground Level Other

Air Bailing Pumping* Other

Test Rate 11 gpm Duration of Test 1 hrs.

Feet of Drawdown 4 ft. Sustainable Yield gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? Yes No Flowing Well? Yes No

Quality

PUMP/PITLESS

Type of pump Capacity gpm

Pump set at ft. Pitless Type

Pump installed by owner

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Complete Well Service

Address 1765 Smute Road

City, State, Zip Ashlar, ON 43003

Signed William H. Paul Date 01/05/04

ODH Registration Number 00155

(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 1/5/04 Total Depth of Well 70 ft.