

WELL LOG AND DRILLING REPORT

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503


957615

WELL LOCATION

CONSTRUCTION DETAILS

County ASHTABUWA Township ORWELL
Owner/Builder LAWRANCE EASTON
Address of Well Location 2985 LIBERTY STREET
City ORWELL Zip Code 44004
Permit No. 123 Section/Lot No. 2985
Location of Well in State Plane coordinates, if available: Use of Well SF
N ☒ X 41 32 12 ft. or m
S ☐ Y 80 59 36 ft. or m
Elevation of Well 838 ft. or m
Datum Plain: ☒ NAD27 ☐ NAD83 Elevation Source GPS
Source of Coordinates: ☒ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat. 41 32 12 Long. 80 59 36



WELL TEST*

Pre-Pumping Static Level 3 ft. Date 9/21/03
Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other
☐ Air ☒ Bailing ☐ Pumping* ☐ Other
Test Rate 5 ft gpm Duration of Test 1 hrs.
Feet of Drawdown 20 ft. Sustainable Yield 5 ft gpm
(Attach a copy of the pumping test record, per section 1521.05, ORC)
Is Copy Attached? ☐ Yes ☐ No Flowing Well? ☐ Yes ☒ No
Quality Good

PUMP/PITLESS

Type of pump _____ Capacity _____ gpm
Pump set at _____ ft. Pitless Type _____
Pump installed by _____

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Wilson Drilling
Address 895 Brownville Rd
City, State, Zip Rome Ohio 44065 9733
Signed Ricky Wilson Date 10/6/03
ODH Registration Number 2261

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other
BOREHOLE/CASING (measured from ground surface)
1 ☒ Borehole Diameter 8 inches Depth 35 ft.
Casing Diameter 8 7/8 in. Length 21 ft. Thickness 1 88 in.
2 ☐ Borehole Diameter _____ inches Depth _____ ft.
Casing Diameter _____ in. Length _____ ft. Thickness _____ in.
Casing Height Above Ground 3' ft.
Type ☒ Steel ☐ Galv. ☐ PVC ☐ Other
2 ☐ 2 ☐ 2 ☐ 2 ☐ Other
Joints 1 ☐ Threaded 1 ☒ Welded 1 ☐ Solvent 1 ☐ Other
2 ☐ 2 ☐ 2 ☐ 2 ☐ Other

SCREEN

Diameter _____ Slot Size _____ Screen Length _____ ft.
Type NA Material _____
Set Between _____ ft. and _____ ft.

GRAVEL PACK (Filter Pack)

Material/Size NA Volume/Weight Used _____
Method of Installation _____
Depth: Placed FROM _____ ft. TO _____ ft.

GROUT

Material Granular Volume/Weight Used 50+
Method of Installation pour & drive
Depth: Placed FROM 0 ft. TO 20 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED. Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.		From	To
Topsoil & brown clay		0	8
some gray lower			
soft gray shale		8	20
lighter gray shale *		20	
water starts at 26'			35

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy